

PLENARY LECTURE

ARTWORK- A REVIEW OF RESEARCH WORK DONE BY PROFESSOR ARTHUR (Art) E. BERGLES

Satish G. Kandlikar
Mechanical Engineering Department
Rochester Institute of Technology
Rochester, New York
USA

ABSTRACT

Professor Arthur E. Bergles has made major contributions in a number of areas in heat transfer. This paper presents a review of 300 papers published by him, and with his students and co-workers, through December 1996. Professor Bergles' research work can be broadly categorized into seven areas: (i) enhanced heat transfer, (ii) two-phase flow and heat transfer, (iii) heat transfer to refrigerants (boiling and condensation), (iv) cooling of electronic components, (v) laminar internal flow, (vi) review and general papers, and (vii) history of heat transfer. This research, conducted over more than 30 years, has produced a wealth of high-quality experimental data, theoretical models, and their practical applications. One of the major objectives of this article is to highlight these contributions and identify their sources, to facilitate future researchers and designers in developing new theoretical models and in designing industrial equipment.

1. INTRODUCTION

The research work of Professor Bergles conducted over a span of over thirty years is a great gift to the heat transfer research community in academia as well as in industry. Professor Bergles, through his extensive reports and publications, helped us all in defining the research needs through his visionary review papers, then identifying for industry the potential benefits of conducting fundamental and applied research work, especially in enhanced heat transfer, and finally as a true researcher to his soul, setting out to obtain invaluable experimental data as well as insight into the underlying mechanisms governing the related phenomena in numerous fundamental problems. It is the best gift to us all from Professor Bergles, that helped define many careers for many of us, and produced and improved many

products for the benefit of mankind.

The experiments conducted by Professor Bergles not only provide valuable data, but also bring out the importance of properly designing an experimental set-up to obtain the desired data by carefully controlling and limiting the influence of extraneous variables. The approach taken by Professor Bergles shows the thoroughness he applies in the design of the entire study covering a specific topic. As seen from his studies on twisted tapes, turbulators, microfins, and porous coatings, to name a few, he has first considered a list of alternatives, and then narrowed it down to specific configurations through broad experimental investigations. This was followed by conducting well thought-out experiments to reveal the most important parametric trends for the targeted configuration, an art he has displayed time and again. From these parametric studies, he has provided specific directions to the researchers in academia as well as in industry. The generosity that everyone has experienced while in his company is evident even in his research work through extensive survey papers written by him giving insights into the fundamental as well as applied aspects of numerous heat transfer related problems.

A list of research publications by Professor Bergles published through December 1996 is included under the list of references¹. The papers are classified into ten categories as shown in Table 1. The numbers in front of a category indicate the paper reference numbers.

¹ The list of references is in a slightly different format. Since there are many papers with the same authors in a given year of publication, the papers are numbered and are listed in a chronological order. The papers are referenced by these numbers in the table and the text (within square parenthesis).

TABLE 1. PUBLICATIONS BY PROFESSOR ARTHUR. E. BERGLES IN DIFFERENT RESEARCH AREAS

RESEARCH AREA	REFERENCES
Subcooled Boiling with Special Emphasis on Cooling of High-Flux Components	4, 5, 18, 25, 33, 43
Fundamental Studies in Enhanced Heat Transfer	6, 8, 10, 16, 17, 24, 30, 36, 40, 45, 47, 51, 53, 56, 59, 62, 64, 67, 76, 80, 85, 90, 91, 93, 99, 103, 104, 114, 115, 116, 117, 123, 127, 128, 130, 136, 138, 139, 145, 147, 148, 152, 155, 156, 157, 160, 161, 164, 165, 171, 172, 180, 181, 182, 191, 192, 193, 194, 196, 199, 205, 209, 212, 213, 214, 215, 222, 224, 225, 226, 228, 230, 231, 232, 233, 235, 236, 237, 238, 239, 246, 249, 250, 251, 252, 258, 261, 264, 265, 267, 268, 270, 273, 275, 277, 278, 279, 281, 282, 287, 288, 289, 290, 292
Fundamental Studies and Reviews of Two-phase flow and Heat Transfer	9, 11, 12, 15, 20, 21, 22, 26, 27, 28, 32, 39, 50, 60, 70, 72, 73, 79, 96, 97, 100, 107, 112, 126, 131, 135, 143, 144, 146, 166, 188, 195, 241, 248, 253, 254, 257, 259, 260, 263, 266, 269, 280, 283, 293, 294, 295
Instability of Two-phase Flows	7, 13, 29, 31, 37, 38, 42, 44, 46, 48, 54, 71, 98
Heat Transfer to Laminar Internal Flows	23, 34, 41, 57, 61, 65, 69, 83, 106, 108, 118, 119, 120, 125, 129, 198, 286, 298
Flow and Heat Transfer of Refrigerants (Including Evaporation and Condensation, pure and oil-refrigerant mixtures)	158, 159, 170, 175, 183, 185, 187, 192, 204, 206, 207, 208, 210, 242, 243, 271, 284 (papers on enhanced tubes covered under Fundamental Studies in Enhanced Heat Transfer)
Reviews of Enhanced Heat Transfer	19, 35, 49, 52, 66, 74, 78, 84, 86, 88, 89, 92, 94, 95, 101, 102, 105, 109, 110, 111, 113, 121, 122, 132, 133, 134, 137, 141, 142, 149, 151, 153, 154, 173, 189, 223, 229, 255, 276, 291, 296, 300
Studies and Reviews of Cooling of Electronic Components	68, 81, 82, 140, 150, 162, 163, 166, 167, 168, 174, 176, 177, 178, 200, 201, 202, 203, 218, 219, 220, 234, 245, 256, 262, 272, 274, 299
General Heat Transfer	1, 2, 3, 14, 55, 58, 63, 75, 87, 169, 184, 190, 197, 216, 217, 221, 227, 240, 244, 247, 285, 297
History of Heat Transfer	77, 124, 179, 186, 211

2. Review of Research in Specific Areas

Table 1 covers all the three hundred papers published by Professor Bergles. The following review presents the highlights and some important details and relevance of his work. Due to space constraints, all the paper listed in Table 1 could not be discussed. Although figures and tables are not included here, the readers can identify the relevant papers from the information presented here, and then refer to those papers to find additional details.

2.1 Enhanced Heat Transfer

Professor Bergles has been one of the most active proponents of enhanced surfaces in heat transfer applications. He has displayed a vision to recognize the importance of enhancement in refrigeration, power, process, and microelectronic cooling applications. In his 1979 paper on energy conservation via enhancement (Bergles et al. [93]),

he outlined the steps needed for developing enhanced surfaces for commercial applications. As stated in his paper, "Commercialization represents the ultimate stage of development; however, even commercial products require additional development work". He is among the first ones to comprehensively address issues related to the application of enhanced surfaces - fouling, manufacturing and development cost, and performance evaluation criteria for their selection. He undertook the task of identifying the underlying heat transfer and pressure drop mechanisms (for internal enhancement techniques) for these enhancement devices, and provided insight which led to further improvements. Vibration, ultrasonics, twisted tapes, bent-strip inserts, finned tubes, microfin tubes, microporous surfaces, microstructured surfaces, and stepped and wavy surfaces are among the enhancement techniques he investigated, providing a rich wealth of experimental data and a better understanding of the heat transfer mechanisms associated with these devices.

2.1.1 Single-phase enhancement

Vibration and Additives. Mechanical vibrations effectively cause localized pressure fluctuations in the liquid adjacent to a heat transfer surface. When the liquid is close to its saturation temperature, enhancement is possible due to nucleation and collapse of bubbles. Professor Bergles became interested in this technique while working on the cooling of high-field electromagnets at the National Magnet Laboratory at MIT (Bergles [6]). To enhance the heat transfer to water flowing in the cooling channels, the channel walls were subjected to vibrations. The localized instantaneous reduction in pressure during a cycle resulted in cavitation in the water at the channel walls. For wall temperatures of about 30 °C below the saturation temperature, the single-phase heat transfer coefficient remained unaffected. However, as the wall temperature approached the saturation temperature, the heat transfer coefficient gradually increased, yielding up to 100 percent increase. The enhancement was reduced as fully developed boiling conditions were established at higher wall temperatures. The effect of ultrasonic vibrations was tested further (Bergles and Newell [8]) with water flowing in annuli. They provided experimental results in a parametric form to show the effect of system pressure, annulus dimensions, vibrational intensity and wall superheat. The presence of vapor in the flow channel drastically reduced the enhancement, indicating the applicability of this technique only to the subcooled region. The tubes were direct electrically heated in the experiments, a technique that Professor Bergles used extensively later with his in-tube research work to obtain local heat transfer data.

Twisted tape and other inserts, and internally finned tubes. Mechanical inserts and internal fins directly affect the fluid flow field and the associated heat transfer process. Twisted tapes and other in-tube inserts have been a major topic of Professor Bergles' research on enhanced heat transfer since 1969. In his first paper on this topic, he reported a detailed experimental study (Lopina and Bergles [16]) on heat transfer and pressure drop with twisted tape inserts with water in fully developed turbulent flow. The enhancement, as much as 100 percent, was attributed primarily to the increased flow path, the increased circulation, and the tape fin effect. An additive model was proposed to predict the heat transfer coefficient from these mechanisms. The contribution to heat transfer due to fin conduction was shown to be small, about 8 to 17 percent, for perfect contact between the tape and the wall. For a constant pumping power, twisted tape inserts provided a 20 percent improvement in heat transfer over an empty plain tube.

Surface roughness and twisted tapes both provide enhancement, although the mechanisms in the two cases are different. The effect of combining these two techniques was investigated (Bergles et al. [24]) in the turbulent region. Since the two mechanisms do not overlap, the combination was expected to provide further improvements, as was indeed the case. The superposition technique worked well for correlating the heat transfer data in spite of highly

non-linear nature of the mechanisms. This helped to clarify the discrepancies between two twisted tape data sets obtained with the same geometry - attributable to the differences in the surface roughness of the tubes.

The effect of brush and mesh type inserts was also studied experimentally (Megerlin et al. [53]) for high heat flux applications. Both inserts yielded dramatic improvements in heat transfer coefficient, up to 1000 percent increase, as compared to plain empty tubes. However, the pressure drop penalty was extremely high, up to twenty times higher in certain cases.

Internally finned tubes are another form of enhancement technique that were extensively tested by Professor Bergles (Bergles et al. [36]). The heat transfer performance of eight internally finned tubes was experimentally obtained under turbulent flow conditions. The effect of roughness was found to be insignificant for the internally finned tubes tested. These tubes showed promise for a heat transfer performance improvement of 25 to 170 percent for a given pumping power.

The twisted tapes were tested for augmentation in the laminar flow region (Hong and Bergles [64]) where a 1000 percent enhancement in Nusselt number was confirmed with water and ethylene glycol, covering Prandtl number ranges of 3-7 and 84-192, respectively, with the two fluids. The experiments were conducted for uniform-heat-flux boundary conditions in a 10.2 mm electrically heated stainless steel tube employing twisted tapes with twist ratios of 2.45 and 5.08. Hong and Bergles [64] developed a correlation scheme for heat transfer and pressure drop that was later extended to non-Newtonian fluids (Manglik et al. [222]). The work of Hong and Bergles [64] was extended to include static-mixer inserts and internally finned tubes (10 longitudinal fins, 1.57 mm height, in a 14.2 mm tube) for process-industry applications (Marner and Bergles [90]). These devices were found to provide a higher heat transfer enhancement ratio compared to the pressure drop penalty in the laminar region as compared to the turbulent region where increases in pressure drop were significant. The study was extended to laminar flow with Polybutene 20 (a liquid polymer manufactured by Chevron Chemical Co., Prandtl number range 1260-8130) by Marner and Bergles [147]. It was found that the internally finned tubes yielded a 400 percent increase in heat transfer coefficient for heating, while the twisted tape inserts were more effective for the cooling applications, yielding 150 to 225 percent improvements over plain tubes. The internally finned tubes yielded only marginal improvements during cooling.

The twisted tape insert results were analyzed (Manglik and Bergles [182]) in an effort to develop a correlation to predict their performance with laminar flow under uniform-wall-temperature conditions. The experimental data on heat transfer indicated a strong influence of five parameters: entrance effect, fluid viscosity ratio (bulk to wall conditions), Prandtl number, tape twist ratio, and swirl flow Reynolds number. The augmentation of highly viscous laminar flow under constant-wall-temperature conditions was investigated in subsequent papers (Marner and Bergles [231], and Manglik and

Bergles [261]), in which extensive experimental data on heat transfer and pressure drop was reported.

The available experimental data for water, ethylene glycol, and Polybutene 20 obtained in earlier studies were correlated within ± 25 percent (Manglik and Bergles [182]). However, this correlation covered a limited range of parameters. In subsequent papers, Manglik and Bergles [264, 265, 277] presented mechanistic parameters to identify the effect of swirl on the flow field. The balance of viscous, convective inertia and centrifugal forces is used to predict the onset and intensity of swirl, as determined by the swirl parameter. Based on this mechanistic description, four regions are identified - viscous flow, thermally developed swirl flow, swirl-turbulent transition, and fully developed turbulent swirl flow. A continuous correlation covering these regions for uniform-wall-temperature conditions was developed. The correlation accurately represents the parametric trends, as well as the asymptotic values for different variables.

Spirally-Grooved (Rope) Tubes. With the large amount of heat transferred in power plant surface condensers, a tubeside enhancement of the heat transfer coefficient could result in considerable savings in the overall plant operation. Spirally-grooved tubes hold the promise of enhancing the heat transfer coefficients on both sides; they are one of the most cost-effective enhancement devices. Professor Bergles saw the need to develop a good correlation scheme for these tubes for design purposes. Rabas et al. [212] compiled a data bank of 458 data points from five different sources. They proposed a new correlation scheme to predict the heat transfer coefficient and friction factor for the spirally-grooved tubes with an overall average error of less than 10 percent with the existing data. This represents one of the most comprehensive correlation schemes which accounts for the geometrical factors and fluid characteristics. One of the benefits of this correlation is that it is possible to clearly see the parametric influences of different geometrical parameters on the performance, providing a valuable tool to the designer who is faced with the selection of an optimum geometry based on not only the thermal, but economic and manufacturing constraints also.

Turbulators for Fire-Tube Boilers Fire-tube boilers employ high temperature gases flowing inside tubes. Since the heat transfer coefficient on the outside is very high with boiling water, it is desirable to increase the heat transfer coefficient on the gas side. The overall objective in this application is to improve the boiler efficiency. Other factors such as pressure drop, air-fuel ratio, changes in the water side heat transfer coefficient, fouling, and manufacturing cost are also important. In an experimental study program, Junkhan et al. [138] and Bergles et al. [145] investigated three commonly employed turbulators in fire-tube boilers (two bent-strips and one twisted tape). The heat transfer enhancements for these three inserts were measured to be 125 percent, 157 percent and 65 percent over a plain

empty tube, while the corresponding increases in pressure drop were 1100 percent, 1000 percent, and 160 percent at a Reynolds number of 10,700. The width of the twisted tape was less than the tube diameter, and this contributed to the lowering of its heat transfer enhancement to about 50 percent of the next best tube, but the corresponding pressure drop was reduced dramatically.

In order to identify the effect of the inserts on the flow characteristics in a fire-tube boiler application, Nirmalan et al. [161] conducted visual studies on seven different bent-strip types of inserts. The heat transfer enhancement was measured to be between 175 and 285 percent at a Reynolds number of 10,000, with corresponding pressure drop increases of 400 to 1800 percent. The visual observations indicate that the flow disturbance is most severe in the region where the bent strip comes in contact with the tube wall. The flow remains relatively intact in the region where the bent-strip does not touch the wall. Increasing the number of contacting points would appear to increase the heat transfer coefficient, however with a further penalty in pressure drop. The perforated-strip insert indicates that the core region also plays an important role in the heat transfer mechanism. The effect of radiation between the strip in the core region and the wall was also seen to play an important role, warranting further studies on this aspect. In a subsequent study, Nirmalan et al. [164] tested three additional inserts. They also addressed the issues raised in their earlier investigation, Nirmalan et al. [161], by constructing separate inserts representing the core region and the wall region of the bent-strip insert. The results indicate that the inserts with more rounded bends have a higher heat transfer coefficient as well as a higher pressure drop penalty. The pitch was seen to play an important role in the entrance region. The-core region insert was shown to enhance the heat transfer much more than the wall region insert, contrary to the earlier assumption that the core may not play as important a role. However, the combined effect of the two regions could be different from the individual influence of each region. Nirmalan et al. [180] presented a theoretical model using a surface renewal/penetration concept to develop a correlation scheme for the bent-strip inserts. In this model, they assumed that a packet of fluid is thrown toward the wall by the insert in the core region. This fluid is heated by the wall during a transient conduction process. The correlation scheme incorporates a constant that is characteristic of the individual insert.

Ravigururajan and Bergles [251] also visually investigated the flow phenomenon near the wall of ribbed tubes. Flow visualization was seen as a useful tool in optimizing the ribbed geometries.

Twisted tape Inserts with Non-Newtonian Fluids. Non-Newtonian fluids are often encountered in chemical, petroleum, food, biochemical, and pharmaceutical industries. Typical fluids in these applications are paints, inks, soap and detergent slurries, polymer solutions, greases, bitumen, paper pulp, corn syrup, mayonnaise, and starch suspensions, which are pseudoplastics. The three basic mechanisms of augmentation, (i) secondary flow effects, (ii) an increased flow path, and (iii) fin effects, are still responsible for

enhancement in non-Newtonian fluids. Manglik et al. [222] conducted an extensive study to investigate the heat transfer and pressure drop for laminar flow of non-Newtonian fluids in uniformly heated tubes with twisted tape inserts. The experiments were conducted with two concentrations, 1.0 and 1.3 percent, of HEMC solution in a 12.85-mm-diameter stainless steel tube. They attributed the increase in heat transfer coefficient with pseudoplastics in single-phase flow to (i) the non-Newtonian effects, and (ii) the variable consistency effects. Using the same correction factors, the Hong and Bergles [64] correlation for the uniform-heat-flux boundary condition was modified to predict the heat transfer results within ± 30 percent. This is quite remarkable, considering that the Hong and Bergles [64] could predict their own water and ethylene glycol data to only within ± 25 percent. Similar treatment resulted in a reasonable agreement with pressure drop data as well [$+25$ percent to -30 percent].

Natural Convection. Natural convection heat transfer is an important mode of heat transfer employed in many applications including cooling of microelectronic devices. It is desirable to extend its applicability to avoid the need for an active device such as a fan or a blower in the cooling system. Augmentation of natural convection heat transfer, therefore, has received renewed interest in last decade.

A systematic study was undertaken by Professor Bergles to investigate augmentation of natural convection heat transfer. Bhavnani and Bergles [157, 239] conducted an interferometric study of laminar convection heat transfer process from an isothermal vertical plate with two types of transverse elements - transverse ribs and transverse steps, placed horizontally across a 127-mm x 178-mm aluminum plate. A Mach-Zehnder interferometer was used for taking local measurements. The effect of pitch, height, and width (in case of ribs) was investigated. It was found that the transverse ribs, in fact, decrease the overall heat transfer rate by creating stagnation zones on both upstream and downstream sides of the ribs. The stepped surfaces helped to improve the performance. The effect of a sinusoidal wavy surface was studied by Bhavnani and Bergles [213, 252]. This geometry resulted in average heat transfer rates very close to plain-surface values. There was an effect of wave amplitude seen in the results. Smaller amplitudes caused the transition to turbulence at lower Grashof number values of around 2×10^7 as compared to a plain vertical surface. It was found that if the lower edge of the plate was curved inside, it resulted in a better performance; however this effect was not significant when two or more cycles of the wavy surface were present along the plate length.

Fouling In Enhanced Surfaces. Fouling in heat exchanger tubes is a major issue that needs to be addressed before enhanced tubes can be employed, especially in critical applications such as utility condensers. With this objective, Somerscales et al. [250], and Bergles and Somerscales [290] carried out an extensive testing program on tubes employing four types of enhancement techniques, namely, the roped or corrugated, helical fins, axial fins, and helical rib

roughness. They conducted the tests with magnesium oxide (approximately 3 μm diameter) as the foulant suspended in distilled water. The tests showed that the tubes with axial fins, helical fins, and rib roughness exhibited a higher fouling rate than a smooth tube under both high velocity and low velocity tests, whereas the roped or corrugated tube showed a remarkably lower fouling rate. However, Bergles [273, 278] reported a review of other works in which the field testing of roped or corrugated tubes showed considerably higher fouling rates with river and sea water. They attributed the main reasons for this discrepancy to the differences in the nature of the fouling elements present in the laboratory testing and the field testing. The water in the field tests contained dissolved salts, biological substances, finely divided sand or silt, and other products of chemical reactions, while the laboratory tests were conducted with a single foulant.

Performance Evaluation Criteria for Single-phase Enhancement. Thermal equipment designers are often faced with the task of selecting an appropriate enhancement device for a given application. Many researchers were working on developing guidelines to help in this selection process during 1960s and 70s. Bergles [19] presented a comprehensive survey of different augmentation techniques, and identified the need to establish generally applicable selection criteria for augmentative techniques. The factors such as development cost, initial cost, operating cost, maintenance cost, reliability, and safety are important in this selection process, but are too difficult to evaluate for general application. The enhancement ratio in heat transfer coefficient, at constant pumping power, length, and diameter, was used to compare different single-phase enhancement techniques. In a subsequent paper, Bergles et al. [45] proposed the eight performance evaluation criteria for augmentation devices. The parameters used in these criteria are - basic geometry, flow rate, pressure drop, pumping power, and heat duty, while the three possible objectives considered are - increase heat transfer, reduce pumping power, and reduce heat exchanger size. With these parameters, the following eight criteria were proposed - (i) for fixed geometry and flow rate, increase heat transfer, (ii) for fixed geometry and pressure drop, increase heat transfer, (iii) for fixed geometry and pumping power, increase heat transfer, (iv) for fixed geometry and heat duty, reduce pumping power, (v) for fixed heat duty and pumping power, reduce exchanger size, (vi) for fixed heat duty and pressure drop, reduce exchanger size, (vii) for fixed heat duty and flow rate, reduce exchanger size, and (viii) for fixed heat duty, flow rate, and pressure drop, reduce exchanger size. They derived specific ratios for each criterion. To include economics, a ninth criterion was introduced by comparing the total annual cost with, and without, augmentation. These criteria have been extremely helpful in convincing the heat exchanger industry of potential benefits of switching to enhanced geometries.

Bergles et al. [59] further modified the performance evaluation criteria to remove the assumption of constant temperature difference

between the hot and cold streams, and to include the effect of the thermal resistances external to the enhanced surfaces. Bergles et al. [62] applied these criteria in the selection of compact heat exchanger surfaces. Webb and Bergles [123] presented algebraic formulations of these criteria for low Reynolds number flows. These criteria are now widely used in the development and selection of compact heat exchanger surface geometries in automotive, air separation, and many other industrial applications. Applying these criteria to the bent-strip inserts in fire-tube boilers, Webb and Bergles showed that a favorable enhancement is achieved in the Reynolds number range of 5000 to 30,000 under a constant pumping power constraint, while the range drops to between 3000 to 5000 under the constant pressure drop constraint.

2.1.2 Enhancement In Pool Boiling.

Vibration and Ultrasonic Techniques. The instantaneous reduction in pressure in the liquid adjacent to a heated surface leads to rapid growth and collapse of vapor bubbles resulting in enhancement in subcooled pool boiling. Such effects of vibration on the subcooled pool boiling heat transfer were studied by Bergles [17] with water as the working substance. An increase in vibrational energy markedly increases the pool boiling heat transfer rates. Also noted was the effect of vibration on the CHF.

Park and Bergles [199] studied the effects of ultrasonics on the heat transfer performance of a smooth pool boiling surface for possible microelectronic cooling applications. They used refrigerant R-113 as the test fluid. The results obtained were similar to those obtained by Bergles [17] in that little enhancement was observed for saturated conditions. Enhancement improved with the subcooling. Burnout heat fluxes were not significantly altered with the ultrasonics.

Low-Finned and Modified Structured Surfaces. The meticulous work by Professor Bergles in revealing the nature and mechanism of nucleate boiling in enhanced surfaces has been outstanding. He combined experimental measurements with visual techniques in revealing the flow of liquid in micropores and channels of enhanced boiling surfaces. His work provided a clear direction for industry in improving the performance of enhanced pool boiling surfaces.

Low-finned tubes were used in pool boiling applications since the 1940s. New surfaces with porous coatings and modified low-finned tubes were manufactured commercially under the names such as High Flux, ECR40, Thermoexcel-E, and GEWA-T. The standard GEWA-K profile is a low finned surface, while GEWA-T is a modified surface in which the GEWA-T fins are formed into a T-shape by indenting a notch in the tip of the fin and then press-rolling the tip. To understand the mechanisms responsible for the higher performance of the GEWA-T surfaces, Ayub and Bergles [156, 181] conducted an experimental study to compare the pool boiling heat

transfer rates for GEWA-T and GEWA-K surfaces. Both surfaces showed more enhancement with R-113 than with water, (maximum enhancement of 100 percent and 60 percent, respectively, with R-113 and water). One of the highlights of the performance of these tubes was the lack of a temperature overshoot at the onset of nucleate boiling. Comparing the performance of various geometries, Ayub and Bergles observed that the gap width between the fins was an important parameter in the thermal performance. The performance of a particular geometry was dependent on the fluid employed - so the idea that each geometry needs to be optimized for specific refrigerant was proposed. The study of the flow pattern near the boiling surface revealed that a predominant pattern of liquid inflow was present at different locations. Liquid entered the finned surfaces at specific locations while bubbles were generated at both sides of these locations. A continuous liquid-vapor exchange mechanism, different than the ones reported before for pool boiling, was observed for these surfaces. They proposed a heat transfer model which suggested that the heat transfer in this geometry is controlled by latent heat transport and agitated natural convection. Professor Bergles recommended that this study should be extended to CHF, and the performance of this geometry studied in tube bundles. This study represents a major step in the understanding and subsequent development of enhanced surfaces in pool boiling applications.

To enhance the performance of a GEWA-T surface further, Ayub and Bergles [196] proposed to fill the gap between the fins with a sponge material, polystyrene di-vinyl benzene polymer. The presence of the sponge was expected to increase the bubble activity in the gap. The pool boiling experiments were conducted on these filled surfaces with distilled water. Experimental results showed that the heat transfer rates increased by a factor of 1.5 to 2.3 relative to GEWA-T tubes with unfilled gaps.

Boiling hysteresis is caused by the fact that the superheat needed to activate a cavity is higher than that required to keep it active after it has been activated. Its effect is pronounced at the onset of nucleate boiling where the higher superheat requirement may cause the surface to overheat considerably before the pool boiling is established. Also, a vigorous explosion on the heating surface accompanies the onset of nucleate boiling in certain cases. The effects of hysteresis were seen to be a major problem in utilizing pool boiling in electronic cooling applications. Ayub and Bergles [214, 237] conducted an experimental study to characterize the hysteresis for GEWA-T surfaces. These surfaces exhibited a small but different kind of hysteresis in which multiple smaller excursions in wall temperature were observed during the transition from natural convection to nucleate boiling. They attributed this to improved natural convection in the low finned surfaces prior to nucleation. The multiple excursions were believed to be due to the isolation of nucleation sites from one another in the helical grooves.

Bergles and Chyu [104, 117, 127] present a study focusing on the hysteresis effect of structured surfaces in pool boiling. They showed that the tubes coated externally with porous metallic coatings showed considerable nucleate boiling enhancement once the nucleate

boiling was initiated. However, similar to smooth tubes, the enhanced tubes tested showed a hysteresis effect that was not reported in any earlier literature. The hysteresis was attributed to the wetting and flooding of the cavities by the liquid, particularly for refrigerants. Bergles and Chyu [127] discuss the problems encountered by temperature overshoot in different industrial applications. The effect of pore size and the heat transfer mechanism in tunnels formed by the microstructures are discussed by Bergles [215] in a comprehensive paper on this subject.

Professor Bergles extended the study of nucleate boiling with water on enhanced surfaces to pure refrigerants R-113 and R-11 and their binary mixtures as reported in Trewin et al. [282]. The tubes tested included smooth, knurled (Turbo-B), and sintered (High Flux) surfaces. Nucleation on these surfaces was initiated in some cases with a wall superheat of less than 0.1 °C. The hysteresis effect was most pronounced for small porosity High Flux surfaces, resulting in an overshoot of 10 °C. The porosity of the High Flux surface played a major role in the heat transfer process. Smaller porosity tubes performed the best (after the nucleate boiling was initiated following the hysteresis effect) among all the tubes tested. Another major conclusion of the study was that the sizes of the channel openings in Turbo-B tubes had very little influence on the heat transfer rate, indicating that the subsurface channel itself plays an important role. They identified thin film evaporation inside the channels as the main heat transfer mechanism in the Turbo-B tubes. The pool boiling heat transfer coefficients with mixtures showed a degradation for all three surfaces, although the enhanced surfaces consistently performed better than the smooth tube. A need for developing better correlating schemes for mixtures with enhanced surfaces was identified.

2.1.3 Enhancement in Two-Phase Flow, Boiling and Condensation.

There is a need for improving the performance of heat transfer equipment incorporating boiling and condensation processes from an energy conservation viewpoint. The benefits to the refrigeration, power and process industry result directly in overall conservation of energy resources. With the rapid advancements in the enhancement techniques for single-phase heat transfer, it was only a matter of time before it was realized that further improvements in flow boiling and condensation heat transfer rates are warranted to improve the overall efficiency of the thermal systems. Professor Bergles addressed this need by conducting extensive research on enhancement in flow boiling and condensation.

Doubly Rippled Surface for External Condensation.

One of the most important factors in determining the external condensation heat transfer is the existing film thickness on the condensing surface. This layer presents a thermal barrier to heat transfer. In applying the pool boiling mode to electronic cooling, efficient condenser surfaces were needed to transfer the heat from the condensing refrigerant to the cooling water. In 1972, Markowitz et

al. [47] developed a doubly rippled surface; the main ripples help to drain the condensate film effectively from the downward facing condenser surface, while the secondary ripples reduce the film thickness on the condenser surface between the main ripples. An analytical formulation was presented to predict its thermal performance by extending the laminar film condensation theory. Although the experiments yielded a lower heat transfer rates than predicted by the theory, a number of practical problems arising in such research work were pointed out. These include the proper degassing procedure, the effect of non-condensables, and the assumption of non-uniform heat flux over the condensing surface.

Twisted tapes, Internally Finned Tubes, Wall Roughness Elements and Microfins for In-Tube

Evaporation and Condensation. The work of Professor Bergles on twisted tapes in single-phase flow has provided an insight into the heat transfer mechanism, and a powerful correlation technique along with invaluable experimental data for this geometry. Professor Bergles saw the potential of twisted tapes in in-tube condensation application, and undertook a detailed study to explore this field. Although condensation enhancement was studied by many investigators, Professor Bergles pointed out that very few efforts were directed toward the in-tube enhancement.

Royal and Bergles [67, 85] conducted a detailed experimental study on the augmentation of in-tube condensation of low pressure steam in horizontal tubes by means of twisted tapes and internally finned tubes. Twisted tapes showed an improvement of 50 percent while the internally finned tubes showed an improvement of 300 percent in heat transfer rates over empty smooth tubes. To make the data useful to practitioners, Royal and Bergles presented correlations for both geometries, using their own data as well as other data available in literature.

The work on in-tube condensation with water was extended to refrigerants by Luu and Bergles [99] for application in refrigeration and air-conditioning. Twisted tape inserts and three different internally finned tubes were tested. Internally finned tubes performed better than twisted tapes. Using performance criteria with a constant pressure drop, internally finned tubes were by far superior, and held promise in commercial applications. Professor Bergles, however, pointed out that the fin geometries resulting in optimum performance for refrigerants are different than those for water. Luu and Bergles [103] presented qualitative reasons for the differences in condensation characteristics of water and R-113. The important parameter is the condensate film thickness, which depends on the surface tension, density ratio of the two phases and the wall shear stress. The twisted tapes were seen as possible retrofit devices in existing condensers.

The wall roughness elements, such as helical repeated rib and spirally fluted tubes, were found to be effective in enhancing the single-phase heat transfer. Professor Bergles investigated their performance for in-tube condensation. Luu and Bergles [114] and

Bergles [139] report that their experimental study on helical repeated ribs and the spirally fluted elements yielded 80 percent and 50 percent enhancement in the heat transfer coefficient over a smooth tube. Correlations for these geometries were proposed.

The use of microfin tubes for condensation application was extensively studied by Professor Bergles. Khanpara et al. [171] compared the performance of one plain and eight microfin tubes for in-tube condensation of R-113. The heat transfer coefficients improved considerably over smooth tube values. The main reasons for the enhancement during condensation were identified as the area increase due to fin effect, thinning of the condensate film, and the disturbances caused by the presence of fins. The effect of fin shapes, fin height, number of fins, and spiral angles were discussed. This information is useful to the manufacturers in the design of new and more efficient microfin geometries.

Microfin tubes were being introduced in refrigeration industry, and with the relatively little flow modification in the bulk flow, they offered a high heat transfer coefficient coupled with a low pressure drop penalty for evaporators as well. Khanpara et al. [165] conducted an extensive study on one plain and eight microfin tubes of different geometry to arrive at the optimum performing tube. They conducted experiments in electrically heated test sections over a range of quality, mass flux and heat flux. The result clearly identified the tube which performed best for refrigerant R-113 over the given range, and changes in the microfin geometry were proposed based on the observed trends.

Khanpara et al. [183] also conducted a study comparing the electrically heated and fluid heated test sections during evaporation of refrigerant R-113 in smooth and microfin tubes. The heat transfer coefficient was same for the two cases at low and medium mass flow rates; however for high mass flux rates, the electrically heated long test section gave 20 to 40 percent higher heat transfer coefficients. Further investigation is needed in this area.

Comparing various enhancement techniques proposed in the literature, Professor Bergles conducted a systematic study to evaluate their performance with refrigerants. Reid et al. [191, 249] compared the performance of five microfin tubes, and a smooth tube with a twisted tape insert, with the performance of two different diameter smooth tubes. The heat transfer coefficients and pressure drops were obtained for these geometries over a wide range of quality, mass flux, and heat flux. This work showed that the microfin tubes with helix angle around 16 to 18 degrees performed well, with a low increase in pressure drop.

The effect of fluid properties on the performance of microfin tubes of different geometries is an important area in refrigeration application. Khanpara et al. [192] compared the performance of different microfin tubes with R-113 and R-22 refrigerants over the range of operating conditions commonly encountered in refrigeration practice. The enhancement in heat transfer was similar with the two refrigerants in the high mass flow region. In the low mass flow region, enhancement was higher with R-113. They emphasized the need to develop a correlation scheme for microfin tubes. Schlager et

al. [230] present a detailed study on evaporation and condensation heat transfer in microfin tubes with R-22. The microfins showed considerable enhancements (factors of 2.3 to 1.6 for evaporation, and 2.0 to 1.5 for condensation). Corresponding pressure drop increases were only 20 to 40 percent. The effect of tube diameter on the performance was insignificant. This shows that a microfin geometry could be applied to different diameter tubes without any modifications. These studies clearly indicate the superior performance of microfin tubes in boiling and condensation. It is therefore no surprise to see their widespread use in refrigeration and air-conditioning industry.

The performance of several microfin tubes in a fluid heated test set-up was tested with Refrigerant R-22 by Schlager et al. [225]. The tests indicated that the performance of all microfin tubes appeared to be closer together. An increase in mass flow rate decreased the evaporative performance. The pressure drop penalty was less than the heat transfer increase, but it increased with increasing mass flow rate.

In practical applications, small amount of oil is generally present in evaporators and condensers of a refrigeration system. Schlager et al. [204] present a detailed study on the effect of oil on the evaporation and condensation heat transfer in a low-fin tube. Refrigerant R-22 was used with a 150-SUS naphthenic mineral oil. Small amounts of oil, below 1.5 percent, led to an improvement in the evaporative heat transfer coefficient for smooth tubes, but the low-fin tube showed very little enhancement. Higher quantities of oil degraded the evaporator performance for the low-fin tube below the smooth tube level. The condensation performance degraded with the presence of oil, but it was less adversely affected compared to smooth tubes. The work clearly showed that the presence of oil in refrigeration systems affects the thermal performance of augmented tube evaporators and condensers.

A similar study was conducted by Schlager et al. [209] to investigate the effect of oil on the evaporation and condensation heat transfer for smooth and microfin tubes. As found in earlier studies, the presence of oil improved the evaporation heat transfer coefficient of smooth tubes. Microfin tubes also exhibited similar trends, although the enhancement was less. The condensation heat transfer coefficient decreased with an increase in oil concentration for both tubes. They also discussed specific effects of oil concentration and mass flux. Subsequently, Schlager et al. [224, 233] found that the effects of 300-SUS oil were similar to those with 150-SUS oil.

Schlager et al. [228, 238] presented the results showing the effect of oil on the heat transfer and pressure drop performance of smooth and internally finned tubes with R-22. The performance trends of the finned tubes were similar to those for the microfin tubes, but were consistently below the microfin tubes. During condensation, both enhancement techniques resulted in lower heat transfer rates, as compared with the smooth tubes with the addition of oil.

Schlager et al. [235, 236] conducted a detailed literature survey and presented design-correlations for predicting the heat transfer coefficients with refrigerant-oil mixtures during evaporation and

condensation inside smooth and microfin tubes. These correlations are extremely useful to the designers of the heat transfer equipment.

The mechanisms responsible for degradation of heat transfer performance in microfin tubes with oil were not clearly understood. Ha and Bergles [270] conducted a careful study to investigate the effect of oil using visual observations and careful mass fraction measurements in the liquid film near the wall. They found that an oil rich layer adhered to the wall, and its thickness increased with oil concentration and mass flow rate. They identified the thermal resistance of this layer as the primary reason for the performance degradation.

Twisted tapes in Dispersed-Flow Film Boiling The swirl flow generated by twisted tapes could be effective in modifying the film-flow and heat transfer behavior in the dispersed-flow film boiling region. Bergles et al. [30, 40] conducted an experimental study to validate these findings experimentally. Their results show that up to 200 percent enhancement is possible with the introduction of a swirl generator in the flow. In this work as well, Professor Bergles considered the practicality of the enhancement device by comparing its performance under a given pressure drop or pumping power condition. Assuming that the swirl flow promotes thermal equilibrium in the two-phase flow, a model was proposed that requires only one “adjustable constant,” the fraction of the tube wall covered by the centrifugal droplets. With an optimized constant, the correlation described the data well.

Enhancement in Film Evaporation

Horizontal spray-film evaporators are employed in desalination, refrigeration, and chemical process operations. Their applicability to ocean thermal energy conversion systems was evaluated by Chyu et al. [130]. Since the ocean thermal energy systems work between small temperature differences, improving the performance of the evaporation and condensation processes in the power cycle is critical. In the evaporator, the nucleate boiling in the film would be important, and porous and microstructures, employed in pool boiling enhancement, are strong candidates. Chyu et al. tested five surfaces and found a considerable improvement over smooth surface performance. However, the performance with spray was below the corresponding pool boiling performance for these surfaces. They attributed the main reason for the poor performance to the unfavorable temperature profiles in the film.

The enhancement with the structured surfaces in falling-film evaporators was investigated by Chyu and Bergles [148, 232]. The surfaces tested include smooth, Wieland-Werke Gewa-T deformed low fin surface, Hitachi Thermoexcel-E tunnel-pore surface, and Union Carbide Linde High Flux porous metallic matrix surface. Falling-film evaporation over smooth surfaces yields higher heat transfer coefficients than the corresponding pool boiling values. The falling-film results for structured surfaces approach the pool boiling results over structured surfaces at high heat fluxes. Distinct effects

were seen in the convective and nucleate boiling mechanisms depending on the surface tested. Effects of film flow-rate and liquid feed-height were of secondary importance. The need was emphasized for investigating the structured surfaces with different fluids for specific applications.

2.2 Review Papers on Enhanced Heat Transfer

One of the most significant contributions made to the technical community by Professor Bergles is in providing with state-of-art reports in many areas, including enhanced heat transfer. He started his work in this area in early 60s, and is still in the midst of publishing various review papers.

His first elaborate review paper on augmentation techniques appeared in 1969, Bergles [19]. He referenced 371 papers in this work, and classified them into following categories: vortex flows, including twisted tape swirl generators; vibration of the heater surface; electrostatic fields; and various types of additives. The non-boiling, boiling, and condensation in free and forced convection, and mass transfer in forced convection were covered. The review included key information from different papers, and offered guidance for practical applications by presenting turbulence promoter data in terms of a pumping power performance criterion. He reported important experimental data in figures, which were carefully drawn to include detailed information on the experimental conditions for which the results are presented. He compiled and presented the experimental investigations in a tabular form to bring out clearly their key features. Through this paper, Professor Bergles raised the standard for presenting the state-of-art review papers, and he himself wrote more than fifty such in-depth review papers on different aspects of heat transfer.

To aid the researchers in narrowing down their search to specific papers, and to help designers find specific references in their field of interest, Professor Bergles started preparing a bibliography of available literature on different topics. Bergles and Webb [35] presented the first such bibliography on augmentation of convective heat transfer. It included references to 472 papers. Professor Bergles then developed an extensive bibliographic collection, resulting in a six-part paper series coauthored with Professor Ralph Webb - [86] and [92] in 1978, [94] and [95] in 1979, and [102] and [105] in 1980. Even with the availability of the computerized on-line services, the exhaustive bibliographic collections, presented under specific categories, are valuable resource for researchers and designers since a computerized search is able to catch only a fraction of the available literature.

Professor Bergles kept pace with the developments in the enhanced heat transfer, and provided critical surveys, which were valuable in determining the potential of a given augmentation technique for a specific application. He constantly updated his reviews on augmentation, and published them periodically since 1969. Reviewing the augmentation of convective heat transfer, he has authored or coauthored the following papers - Bergles et al. [49],

[52], [66], [84], [88], [89], [109], [110], [111], [132], Bergles et al. [149], [151], [173], and [189]. References [153] and [154], published in 1986, deal with enhancement in high temperature applications. A major part of Professor Bergles' research activity was directed toward the enhancement in boiling and condensation applications. He presented his first paper in this area, Bergles [74] in 1976, and has steadily reported latest compilation of research work - [78], [134], [142], and [229].

Professor Bergles presented extensive review papers on the effects of temperature-dependent fluid properties on laminar flow heat transfer [119, 120] and enhancement techniques in the laminar flow region (Joshi and Bergles [129]). In laminar flow enhancement, his review papers, Joshi and Bergles [113] and Bergles and Joshi [122], provide an extremely valuable resource for selecting a specific type of enhancement device, and understanding the underlying enhancement mechanism occurring in it.

Professor Bergles classifies the enhancement techniques, implemented in last twenty years or so, as second generation heat transfer technology. Starting with the smooth tube as the first generation, the finned surfaces and the 2-D structured surfaces are classified under second generation enhancement technology. Starting in 1983, Professor Bergles has extensively reviewed the second generation enhancement devices in the following papers - Webb and Bergles [137], Bergles and Webb [141], [223], [255], [276], [291], and [296]. The current thrust of Professor Bergles' work, as described in his recent paper, Bergles [300], is toward the third generation enhancement technology that includes 3-D roughness elements, 3-D fins, microfins, and metallic matrices. Although some of these techniques have been invented many years ago, their widespread acceptance in industrial application really determines their "age."

2.3 Laminar Internal Flow

Professor Bergles started his work on laminar internal flow with an extensive study of the effect of natural convection on heat transfer, in fully developed laminar flow of water inside a tube, with uniform heat flux at the wall (Newell and Bergles [23]). This study included the effects of the circumferential variation in the wall temperature by considering two limiting tube-wall conditions - infinite-conductivity tube, and glass-tube (having the same thermal conductivity of the wall material as the test fluid, water). At low Reynolds numbers, a secondary flow due to natural convection is established, which is symmetrical about the vertical plane passing through the axis of the tube. The flow field is three-dimensional, spiraling, in character. The governing differential equations employed stream functions, and were solved using a finite difference formulation. Results were presented in terms of detailed parametric relationships. To make the results useful to designers, correlations for Nusselt number, and a pressure drop parameter, (friction factor \times Reynolds number) were presented as functions of bulk temperature, heat flux, and tube radius. Computer limitations did not permit extensive solutions with

secondary flows in the entrance region. Bergles [34], in a later technical note, discussed the applicability of different assumptions, such as constant wall temperature, Prandtl and Reynolds number effects, and the entrance region effect.

After analyzing the combined convection problem analytically, Professor Bergles undertook the experimental work to verify the numerical results. Bergles and Simonds [41] conducted experiments with electrically heated, coated glass tubes, using water as the test fluid. The final correlation, presented in a graphical form, covered both, the developing and the fully developed flow regions. The heat transfer results were much higher (about 3 times higher for a Rayleigh number of 10^6 in the fully developed region) than the corresponding constant property solution. In this work, Professor Bergles has shown a mastery in designing experiments to obtain meaningful information regarding a phenomenon, while providing useful design correlations to engineering practitioners. We see this throughout his experimental work in many different areas.

Hong et al. [57] extended the numerical and experimental work to combined convection in electrically heated metal tubes. Their results agree with theoretical analysis; the results for the metal tube lie between the constant heat flux and the constant wall temperature cases. A correlation was presented for Nusselt number by including a parameter representing the ratio of the fluid to wall thermal conductivities. Morcos and Bergles [61] included the effect of variable properties in the laminar fully developed region. The mean film temperature was employed to account for the property variations rather than a viscosity correction factor. Hong and Bergles [69] presented analytical solutions for the combined convection with fully developed laminar flow in a circular tube by considering the temperature-dependent viscosity. The results were then correlated in simple forms to cover a wide range of parameters. The results with variable properties lie 50 percent above the results for the constant property solution.

To gain a further insight into the heat transfer mechanism with twisted tape inserts, Hong and Bergles [65] studied the laminar heat transfer in the entrance region of a semicircular tube with uniform heat flux. They later employed the results of this work in the models developed for twisted tape inserts. Hong and Bergles [83] present the analytical solutions for developing and developed flows, and show that the heat transfer rate is increased by 200 percent, and the entrance region is reduced to one-tenth, by including the variable property effects.

Joshi and Bergles [106, 108, 125] analyzed laminar flow heat transfer in circular tubes, with uniform wall heat flux, for non-Newtonian fluids. They compared the results of the analytical study with available correlations. Using their own experimental data covering a broad range of parameters, they presented two correlations based on the temperature dependence of the rheological characteristics of the fluid. Joshi and Bergles [118, 129] extended the study to the uniform wall temperature case.

The papers by Professor Bergles on enhancement in laminar region are summarized in Section 2.5 under review papers.

2.4 Heat Transfer to Refrigerants (Boiling and Condensation Heat Transfer)

A major part of Professor Bergles' research work has been directed toward the refrigeration industry. His work on the enhanced tubes (especially microfin tubes) for boiling and condensation is noteworthy, and is covered under section 2.1.3. In this section, his work on other aspects of heat transfer to refrigerants is covered.

Although much of the research in academia is directed toward pure refrigerants, most refrigeration systems employ oil refrigerant mixtures to provide lubrication to the compressor in the system. With fluorinated hydrocarbon refrigerants, oil is soluble in refrigerant, and is carried over from compressor to condenser and evaporator. Baustian et al. [158] report a study summarizing predictive methods for thermophysical and transport properties of oil-refrigerant mixtures. To determine the oil concentration in the mixture, Baustian et al. [159, 170] reviewed different electrical and optical properties as possible bases for real-time measurements. They recommended two types of measurements - capacitance measurement and refractive index measurement. Continuing this study into the experimental phase, Baustian et al. [206, 207, 208] built and tested three concentration measuring devices based on the density, viscosity, and acoustic velocity respectively. These devices provide practical solutions in the refrigeration industry for on-line measurement of oil concentrations.

Continuing with the practical problem of oil-refrigerant mixtures, Manwell and Bergles [242] presented an experimental study of gas-liquid flow patterns with Refrigerant R-12. They conducted the study with smooth and micro fin tubes. The presence of oil caused foaming, which wetted the walls, and formed foamy slugs in the evaporator. This explains the improvement in the heat transfer coefficient with addition of oil to pure refrigerants in smooth tubes. Since the wetting phenomenon is already present in micro fin tubes, the presence of oil does not necessarily improve the heat transfer. Further, they did not observe the foaming behavior in microfin tubes. This study seems to be the first one to address the mechanism of enhancement with oil-refrigerant mixtures in smooth and microfin tubes.

The oil concentration in evaporator and condenser plays an important role in the heat transfer mechanism. Schlager et al. [243] measured these oil concentrations as functions of heat and mass fluxes, and exit superheat. As expected, with the exiting refrigerant closer to saturation, the oil concentration in the evaporator increased. The experiments showed that the concentrations in the evaporator were as much as three times, and those in the condenser were about twice the average concentration in the system.

Professor Bergles conducted extensive heat transfer measurements in evaporators and condensers with oil in smooth and microfin tubes. This work is reviewed under section 2.1.3 under enhancement in two-phase flow.

Stratification effects in horizontal evaporators cause circumferential variation in heat transfer coefficient. Ha and Bergles

[271] conducted a detailed experimental study to measure this variation as a function of other system parameters. The effect of axial wall conduction influenced the heat transfer coefficient by only 10 percent. In runs with clearly separated flow, the heat transfer coefficient at the base was 3-5 times higher than the average value. The importance of liquid film for evaporation is confirmed, indicating severe deterioration in heat transfer in the upper part of the tube exposed to vapor in the stratified flow.

Ha and Bergles [284] present a valuable discussion on the effect of the type of heating on the heat transfer mechanism in boiling systems. They compared electric resistance wire heating, direct electric heating, and liquid heating, and listed advantages and disadvantages of each method. The paper provides valuable insight on the heat transfer mechanism in smooth and microfin evaporator tubes, with pure refrigerant and oil-refrigerant mixtures. The dryout toward the exit of the evaporator is delayed with microfin tubes, resulting in a significant increase in the heat transfer performance of these tubes.

2.5 Fundamental Studies and Reviews of Two-phase Flow and Boiling Heat Transfer (Including Boiling, and Two-phase flow Instabilities)

Professor Bergles addressed many current issues in two-phase flow, boiling heat transfer, and CHF under different configurations - pool boiling, subcooled flow boiling, and saturated flow boiling. To cover his contributions, his publications in these two broad areas are presented under the following specific subsections.

2.5.1 Two-phase Flow Regimes and Flow Structure.

Flow patterns in two-phase flow were studied by early investigators with air-water, and oil-gas systems under adiabatic conditions. To understand the heat transfer in high pressure boilers applied to the nuclear industry, Bergles and Suo (9) undertook an experimental study to identify the flow patterns under diabatic conditions. They investigated the effect of tube length, system pressure, mass flux, and inlet subcooling in vertical upflow. They identified the flow regimes primarily with an electrical resistance probe. They also took high-speed still pictures, but the resistance probe was found to be more useful in establishing different flow patterns. Changes in pressure, tube length, and inlet temperature significantly affected the flow regime boundaries. Bergles et al. [11] conducted a similar study with low pressure water, and developed composite flow pattern maps to illustrate the effects of pressure, length, and inlet temperature on the flow regime boundaries. Focusing on the spray annular regime, Bergles and Roos [15] measured the film thickness, and obtained the first evidence of smooth dryout at low velocities. The film produced a fluctuating signal in the electrical probe, pointing to a possibility of nucleation, or entrained vapor, in the film close to the dryout conditions.

Professor Bergles realized the importance of two-phase flow in rod bundles as applied in nuclear steam generator application. Bergles [26] investigated the two-phase flow structure visualization with high pressure water in a rod bundle, and found significant differences in flow patterns in different subchannels. Using the electrical resistance probe, he measured the film thickness in the subchannels, and reported extensive data on flow regimes as a function of quality and mass velocity. Significant differences were also reported between the diabatic and adiabatic conditions. The flow regime boundaries were shifted to lower quality with heat addition. The electrical probe was thus seen as a useful tool in sensing an imminent CHF condition.

Another aspect investigated by Professor Bergles was the two-phase critical flow under diabatic conditions, which is relevant in studying the accident conditions in nuclear reactor safety analysis. Bergles and Kelly [27] conducted experiments with water, and found that for qualities below 0.04, the earlier models developed for diabatic flow underpredicted the flow rate.

2.5.2 Two-Phase Flow Mechanism, and Instabilities.

Evans et al. [20, 32] studied the propagation of shock waves in different two-phase flow regimes with air-water flows. The presence of entrained liquid mist was confirmed to have an enormous effect on the pressure wave propagation, and little or no acoustic energy was transmitted through the liquid film. The flow regimes, such as slug flow and annular flow, influenced the pressure wave propagation considerably. This fact explained some of the discrepancies in the data reported earlier in literature. Yadigaroglu and Bergles [31] conducted experiments with Freon-113 to study the density wave oscillations, and observed higher mode oscillations, transmitting at a fraction of the transit time through the channel. They also presented a stability map to explain the phenomenon.

2.5.3 Instrumentation In Two-phase Flow Professor Bergles refined the art of experimentation by using many new instrumentation techniques. In one of his papers, Bergles [21] presented an excellent survey of electrical probes in the study of two-phase flows. He described the core-wall conductivity probe used in determining the flow pattern, void fraction, and liquid film thickness. This study provides a very useful source to anyone who wants to develop these probes. Also, he compared the accuracy of measurements of the electrical probes with other techniques.

More recently, Bonetto et al. [253] used a hot wire anemometer, and developed a probability density function to obtain the information regarding void fraction, bubble size, and vapor velocity from flow boiling experiments. Carvalho and Bergles [254] further applied the hot wire anemometer to measure the local void fractions in pool boiling of FC-77 over small vertical heaters, simulating immersion cooling of electronic chips. The low contact angle of FC-77 yields in

a more satisfactory discrimination between the two phases. They also found the optimal sensor temperature corresponding to 60°C, which was much higher than those reported in earlier studies.

2.5.4 Pool Boiling Heat Transfer. Pool boiling heat transfer data is generally obtained under steady-state conditions. Thompson and Bergles [28] investigated the applicability of the pool boiling curve to quenching problems. They found large differences between the quenching data and the predictions from pool boiling correlations. The presence of surface deposits on the material being cooled disturbed the vapor film and caused early transition to nucleate boiling, thereby reducing quench times below the conventional boiling predictions. Further, it also implied that the transient techniques are not suitable for obtaining the steady-state pool boiling curve.

Another major factor affecting pool boiling data in industrial applications is the presence of contaminants. Jensen et al. [97] experimentally studied the effect of Cosmoline, JP-4, turbine oil, and phosphate on the pool boiling curve. The presence of Cosmoline improved heat transfer rates, the highest coefficient being obtained at the highest concentration tested (1000 ppm). However, DNB occurred at lower heat fluxes compared with distilled water. JP-4, on the other hand, had no influence on heat transfer or DNB. Turbine oil produced erratic results, sometimes causing explosive bubble formation on the heater surface. At high concentrations, the heat transfer results were dramatically below the distilled water curve. DNB was also decreased with the addition of turbine oil. Addition of phosphates generally shifted the contaminant pool boiling curve back to normal, though the DNB occurred at the same level as with the contaminants. The orientation, vertical or horizontal, did not affect the boiling characteristics with or without contaminants.

Carvalho and Bergles [283] studied pool boiling over small vertical heaters, similar to electronic chips, and identified different regimes, rogue sites, incipient boiling, patchy nucleate boiling, fully developed nucleate boiling, and vapor coalescence (leading to dry patches). Using a hot wire anemometer, they obtained void fraction profiles near the heater surface as a function of heat flux. They established the formation, and subsequent propagation of dry patches as the mechanism leading to CHF in pool boiling.

2.5.5 Subcooled Flow Boiling Heat Transfer. In one of his first papers, Professor Bergles presented an often referenced paper on the forced convection boiling heat transfer with Professor Rohsenow, Bergles and Rohsenow [4]. They analyzed flow boiling heat transfer with subcooled and saturated liquids, and presented a criterion to determine the size ranges of nucleating cavities for a given superheat and flow conditions. Also, the heat transfer rates in the region between the forced convection and the fully developed boiling is interpolated using the inception point as the starting point

on the line representing forced convection heat transfer, and merging with the fully developed boiling curve. This inception condition is still widely used in the current literature in many different geometries, from smooth tubes to complex ink jet printer heaters.

Bergles and Dormer [18] conducted extensive experiments to study the pressure drop in subcooled boiling of low pressure water in 2.5-4.0 mm diameter tubes. The pressure drop data was then correlated in a chart form, and curves were presented to cover the entire data. This was one of the first studies in this area. The information is useful in studying stability of multichannel systems as well.

Professor Bergles studied the nucleation phenomena in subcooled boiling systems, and noted that a larger amount of superheat is needed for a given cavity than predicted from theoretical considerations. Murphy and Bergles [43] attributed this effect to the dissolved gases that increased the total pressure in a cavity. However, it was found that with fluorocarbon systems, large superheats were required to initiate nucleation. This caused the "hysteresis" effect, which they attributed to the total flooding of the cavities with low contact angle fluids, such as fluorinated refrigerants. The commercially available porous surfaces tend to prevent the deactivation of the cavities.

Vandervort et al. [266] studied the subcooled flow boiling of water in a 2 mm diameter tube under high heat flux boiling. They observed streams of small diameter bubbles (estimated to be 3 μm) at the exit section of the tube. They presented a detailed description of the forces acting on the bubble and the associated heat transfer mechanism. They believed that Marangoni force was the dominant force, followed by surface tension and drag. The discussion presented in the paper provides a good basis for developing a mathematical model describing subcooled boiling heat transfer near CHF.

Tong et al. [294] investigated pressure drops in small diameter tubes with subcooled flow boiling of water. The earlier work by Bergles and Dormer [18] was extended with 1.05-2.44 mm diameter stainless steel tubes. The subcooled boiling pressure drop was found to be directly proportional to mass flux and length to tube diameter ratio, but inversely proportional to the tube diameter. They developed a pressure drop correlation which is particularly useful in designing cooling systems to accommodate high heat fluxes.

2.5.6 Flow Boiling Heat Transfer In Enhanced Tubes.

This is covered earlier in the section on enhanced heat transfer, Section 2.1.3.

2.5.7 CHF In Pool and Flow Boiling. CHF studies are important in designing flow boiling systems for cooling high flux systems, such as electromagnets. These devices use narrow diameter passages due to space restrictions. Much of the CHF data in

literature pertained to large diameter tubes. To close this gap, Bergles [5] undertook a detailed experimental plan to generate data on CHF for flow of water in 1.5 to 4 mm diameter, electrically heated, stainless steel tubes. Small diameter tubes were found to give a higher CHF than large diameter tubes, making them especially suitable for high-flux cooling systems. Flow oscillations due to an upstream compressible volume was found to reduce the burnout heat flux considerably. Earlier studies which recorded a lower CHF were believed to be affected by this problem. Bergles et al. [11] and Bergles and Kelly [27] conducted additional experiments with subcooled water at low pressure. Choked flow was found to be prevalent under these conditions. CHF was found to be a complex function of both local and inlet conditions.

High pressure water is used in power generation systems, and CHF data is needed in designing these systems. Spray-annular flow pattern occurs at higher qualities, and is of interest in most two-phase systems. Bergles and Roos [15] conducted experiments in recirculating high-pressure steam loop, which reduced the expenditure considerably. Film thickness was measured with an electrical probe, and was found to gradually decrease to zero as the CHF was approached. Measurements in rod-bundles indicated wide variations in film thickness over tubes.

Professor Bergles extensively used many visualization techniques to obtain a good physical picture of complex phenomena. Fiori and Bergles [25] developed a series of films to study burnout in subcooled flow boiling.

Utilizing the experimental data and the photographic information of the CHF phenomenon, Fiori and Bergles [33] proposed a model in which stable dry spots are formed underneath bubbles, and these spots can no longer be quenched at higher heat fluxes, leading to vapor patches covering the heater surface. They presented a comprehensive discussion on possible mechanisms leading to CHF based on the information from Fastax (1200 frames per second) camera and microflash photos.

Bergles [60, 72] surveyed the available literature and provided a comprehensive coverage on the description of the burnout phenomenon in pool boiling with different heater configurations, and different CHF augmentation techniques. This paper presents useful summary, and more importantly, future directions for researchers. Similar reports were presented by Bergles [73] for the low quality forced convection systems, and by Bergles [100] for the high quality forced convection systems. These comprehensive surveys provide a clear picture of the parametric trends and effects of important system variables on CHF. For the pool boiling systems, Park and Bergles [195] collected 2237 data points for CHF and fitted polynomial curve fits to provide engineering equations for system designers.

In a shell and tube evaporator, the tube length covered by baffles may be considered to be under pool boiling conditions. Since the liquid supply is restricted, the burnout condition could be initiated at this location. Jensen et al. [70] studied the dryout in pool boiling under restricted annular geometries and found that the dryout condition occurred at lower clearances and larger widths of baffle

coverage. However, the pool boiling curve shifted to the left, indicating a more efficient heat transfer under the restriction. Jensen et al. [70] attributed this increase to the thin film evaporation in the clearance space.

CHF remains a major concern in high heat flux systems. Vandervort et al. [241] conducted an experimental study in forced convection systems with water in stainless steel tubes having diameters ranging from 0.3 to 2.7 mm. Mass fluxes ranged from 5,000 to 40,000 kg/m²-s, and subcoolings ranged from 40 to 135 °C. In some preliminary tests, a maximum heat flux of around 10⁸ W/m² was achieved. The CHF was shown to increase with both velocity and subcooling. Small diameter tubes provided a higher CHF. More detailed data are presented by Vandervort et al. [280].

In cooling of electronic chips with pool boiling liquid, the heater thickness affects the CHF. Carvalho and Bergles [259] studied this effect, and found that none of the conventional parameters such as wall capacitance, thermal conductivity, or thermal diffusivity were able to correlate the CHF data well. Carvalho and Bergles [259] verified the new parameter "compacitance", which consists of the heater thickness, and heater material thermal properties. Although a considerable data spread is still observed, this work represents a major step in formulating CHF for thin heater geometries. Using the same parameters, Golobic and Bergles [260] proposed a new correlation which correlated their own experimental data for strips cooled on both sides with an average absolute deviation of less than 10 percent.

The mechanism of saturated pool boiling CHF was discussed by Bergles [257]. The two competing theories, hydrodynamic stability theory and microlayer dryout interpretation were discussed. Knowledge of the flow pattern near CHF was deemed necessary to clarify the situation for flat heaters, which forms the basis for other geometries as well.

2.5.8 CHF in Helically Coiled Tubes. Helically coiled tubes are used in industries for single-phase, evaporating and condensing flows, and many other applications. At the system start up, the subcooled boiling conditions sometime lead to the CHF condition, which is not well studied in the literature. Jensen and Bergles [107, 126] conducted experiments to obtain CHF data with R-113 in 0.762 mm diameter tubes. The data was correlated and it was found that an additional parameter consisting of non-dimensionalized radial acceleration was able to account for CHF in helically coiled tubes. The CHF in these tubes was lower than the straight tubes. Undesirable upstream dryout was found to occur if the coil was operated under low subcooling or low quality near the inlet, and in the high quality region near the exit.

Jensen and Bergles [131] studied an interesting problem of practical importance in solar energy applications. A helically coiled tube in this application experiences a higher heat flux on the outside surface receiving the solar energy directly. Such a heat flux tilt was found to reduce the CHF. Jensen and Bergles predicted that the liquid film was disrupted with the heat flux tilt. They correlated the

data in terms of an additional parameter representing the maximum to average heat flux ratio. The problem of non-uniform circumferential heating is of interest in nuclear applications as well.

2.5.9 Reviews and Summary of Two-phase Flow and Boiling Heat Transfer.

Professor Bergles directed his efforts to promoting a clear understanding of many heat transfer phenomena through critical literature reviews. He also placed a major emphasis on the undergraduate education, as is clearly seen in his publication dealing with laboratory experiments demonstrating the bubble behavior in pool and flow boiling, Bergles and Griffith [12]. The experiments were designed to visualize the bubble behavior with varying subcooling, and varying velocity as well in forced flow boiling.

An overview of current information and its relevance to specific applications is essential to keep the researchers in tune with the needs of the industrial community. In one of his early papers, Bergles [96] provided such a link by indicating future needs in two-phase flow research. Multi-beam x-rays, rotating heat pipes, OTEC power plants, and PWR reactors were the examples he used in identifying the research topics requiring further attention.

Bergles [112] presents a good description of heat transfer mechanisms associated with reactor thermal-hydraulics. He discussed incipient boiling, nucleate boiling, burnout, post-dryout, and quenching. The quenching phenomenon is of interest in reactor cooling under accident conditions. Additional effects due to the transient nature of the process makes it different than that described by the steady-state pool boiling curve.

Continuing in the area of nuclear thermal-hydraulics, Bergles [135] presented a comprehensive picture of the heat transfer related issues related to PWR and BWR reactor systems. The specific issues related to boiling heat transfer are then discussed in further detail. Bergles [144] provides some of the empirical correlations used in the steady-state and transient analysis of nuclear reactors.

Boiling heat transfer is a complex phenomenon, and many research papers are published every year. It is therefore very difficult for design engineers of two-phase heat exchangers to keep track of latest developments. Bergles [188] presented clear information on various heat transfer mechanisms in two-phase heat exchangers. He also compared various design correlations, and made specific recommendations. It should be a useful reference for anyone planning to work in this area, and also for those who want to clarify some of the difficult concepts underlying theoretical models available in the literature. Bergles [269] provides similar information on boiling heat transfer pertaining to a single tube in a large pool, and a single vertical tube. This work provides a basis for studying boiling in other more complex geometries such as rod bundles, and multiple vertical channels.

2.6 STUDIES AND REVIEWS OF COOLING OF ELECTRONIC COMPONENTS

Bravo and Bergles [68] reported the performance of a small enclosure with one wall heated and the other wall cooled, and evaporating-condensing liquid/vapor in the enclosed space. They studied the effect of power level, heater geometry, and dissolved gases on the heat transfer rates. This geometry is of practical interest in electronic cooling applications.

Bergles et al. [81] present a “representative” survey of the state-of-the-art, (1977), of heat transfer technology in electronic packaging. They identified that the air cooling would continue in a wide spectrum of cooling applications, including portable devices and medium to large systems. Direct liquid cooling then appeared to be reaching “maturity,” but was not quite ready for industrial applications. Liquid rejection systems, such as heat pipes, and sophisticated technologies were expected to migrate from laboratory to industrial products. They predicted that computer analysis tools would become standard in the thermal design of electronic packages. Looking back, their conclusions drawn in 1977 seem to be right on target.

Bergles [82] presented a paper on the evolution of cooling technology for electrical equipment and electronic devices. He quoted Mouromtseff from his 1942 paper as writing “Without exaggeration one may state that in designing electronic tubes there are more mechanical, metallurgical, and heat engineering problems than those of pure electronic in character.” This statement was true when Mouromtseff wrote it in 1942, was valid when Professor Bergles quoted it in 1977, and as Professor Bergles often mentions in his papers and talks, is still valid in spite of great strides made in computer technology. Professor Bergles, however, pointed out, contradicting Mouromtseff that the analytical tools, and not cut-and-try methods, would become the favored design tools. In this paper, Professor Bergles skillfully takes the reader on a journey of electronic highways, passing through a densely packed thermal section.

Advanced cooling techniques are being constantly introduced in electronic packaging applications. In keeping pace with these developments, Bergles [162] presented a keynote address in which he described the additional developments - such as the thermal conduction module - taking place in the industrial world.

With the advancements in liquid cooling, Bergles [178] presented a comprehensive survey paper on liquid cooling of electronic equipment. The paper presents many milestones in the development of the liquid cooled systems, with details of some advanced systems (TCM, microscopic channels, and open bath cooling of MCMs).

Bergles [200] provides a good summary of high flux boiling systems as applied to microelectronic cooling. He discusses many issues related to pool and flow boiling systems. Nakayama and Bergles [218] present a comprehensive overview of microelectronic cooling in relation to advanced chip cooling systems.

Bergles and Bar-Cohen [262, 272] provide a detailed account of direct cooling of microelectronic components. They summarize the

historical development, and present detailed information on a number of advanced systems using liquid cooling approach. This should serve as a reference for researchers and industry engineers for any liquid cooling system development.

To improve the heat flux densities of microelectronic chips, Ma and Bergles [140, 166] studied boiling jet impingement cooling. R-113 jets were directed against simulated chips. They identified subcooled jets as the most promising way to cool the chips efficiently. Tien et al. [203] introduced nitrogen gas jets impinging on the chip surface submerged in a pool of liquid of low volatility (kerosene), with substantial enhancement in heat transfer rates. Ma and Bergles [219] further conducted experiments with R-113 systems and developed a theoretical model to predict the heat transfer in this two-phase two-component system.

Continuing further on the application of boiling to cooling of chips, Park and Bergles [163, 201] studied the effects of size on the heat transfer coefficient and CHF using simulated chips. They also studied effect of mounting - flush or protruding - on the heat transfer performance of the chips. The results were presented in a graph, and they also developed a correlation for predicting the CHF for different configurations. An interesting fact observed by them was the deactivation of cavities with decreasing heat flux, a phenomenon called by them reverse overshoot.

Another way of improving the performance further is to use enhanced pool boiling surfaces on the microelectronic chips in pool boiling with FC-88. Park and Bergles [168] studied the performance of simulated chips with four types of enhancements - microhole, microfin, Linde High Flux, and Thermoexcel-E. The temperature overshoot and the thermal performance with increasing and decreasing heat fluxes were compared for these surfaces. The High Flux surface provided the best performance overall.

Porous surfaces are used for enhancing pool boiling heat transfer. These surfaces are prepared from a sintering process. The sintering particle material, size, and the processing govern the structure of the sintered surface. Kim and Bergles [174] conducted an experimental study to investigate the effect of various parameters on the pool boiling performance in microelectronic application using R-113. Three sizes of copper particles were used. In the fourth sample, they employed three layers with different particle sizes. The performance of all surfaces was above the plain surface, but the overshoot still posed a problem.

Park and Bergles [177] employed heat sinks to enhance the heat transfer from chips immersed in liquids. Fins with holes and slots were used with R-113. They did not observe the typical temperature overshoot with these devices. The temperature overshoot problems were reduced by Bergles and Kim [202] by introducing an additional heater below the chip surface to provide the initial nucleation sites. Continuing with this work, Bergles et al. [234] developed porous surfaces by etching in-situ copper-niobium alloy. The copper matrix was preferentially etched away, and the surface was cold-rolled to provide re-entrant cavities. The temperature overshoot was considerably reduced with these surfaces.

Park et al. [220] studied the performance of simulated microelectronic chips with different fluorinert liquids. They also experimentally measured performance with different enhancement devices. This work is expected to lead into the development of optimized surfaces for different fluorinert liquids.

Carvalho and Bergles [245] conducted an experimental study to determine the effect of subcooling on nucleate boiling and CHF of simulated microelectronic chips. They tested several enhanced surfaces. They found subcooling to be ineffective in improving the performance at high heat fluxes. The CHF however increased with subcooling. Further research in this area is warranted to clarify some of the issues raised in this paper.

The more commonly employed natural convection heat transfer in cooling of electronic chips was studied by Park and Bergles [150, 176]. They used R-113 and water as the test fluids on simulated chips. The effect of width for small heaters was documented. The heat transfer coefficient increased with decreasing width, with the effect greater in R-113 than in water. This effect was incorporated in a correlation, the first of its kind, to predict the natural convection heat transfer coefficient for small heated surfaces. They also investigated effect of arrangement - in-line or staggered, and spacing between the heaters - for arrays of chips mounted on a vertical surface. They also noted that protruding heaters performed about 14 percent better than the corresponding flush heaters.

Cooling of multiple chips by natural convection poses additional problems due to interaction through the fluid stream flowing over them. Milanez and Bergles [167] studied the effect of a lower heater on the heat transfer from an upper heater. The lower heater enhances the flow of the fluid, but the fluid is also preheated. They measured the performance of two line heat sources simulating the electronic chips, and compared them against analytical solutions. This study addresses the practical problem encountered in designing electronic systems consisting of multiple heat sources, each with different thermal requirement and characteristics. This work was extended to the immersion cooling of multichip modules (MCMs) by Zitz and Bergles [274]. They developed a detailed computerized test system to monitor the vast amount of data generated by the MCM module in the entire range covering natural convection cooling, pool boiling, and CHF. The development of such advanced test facility is a result of a multiple series of works initiated by Professor Bergles and other team members on different aspects of immersion cooling.

2.7 HISTORY OF HEAT TRANSFER

Advancement of technology in various fields is a result of available tools and technological needs of the society at a given time. Scientists and inventors focus their energies in obtaining solutions to make a difference in the lives of people. Inventions of steam, gasoline, and diesel engines transformed the transportation scenario world-wide. The replacements were made in stages, to meet the perceived demands of the marketplace, without stepping ahead too much of the times, achieving a balance among the market forces.

Such developments have taken place in many different fields. The current computer revolution deserves an entire chapter in the technological history books.

Knowing the historical development stages in heat transfer technology is important to all of us, the heat transfer engineers. It gives us a sense of reference, and relevance, while deciding our future research directions. Professor Bergles over the years acted like a historian in search of original publications and major events related to heat transfer. He read the papers published in 1700s, 1800s and early 1900s carefully, and presented a concise summary removing some misconceptions that crept in the literature regarding the origins of many concepts and terms used currently in heat transfer practice.

In his keynote address in 1976, Bergles [77] presented some historical developments, dating from 1756, drawing from many sources, with authors like L. S. De Camp, K. J. Bell, A. F. Burstall, and E. S. Ferguson. With clear sketches and interesting photographs, he described the first steam engine (Heron's whirling aeolipile), Watt's single-acting steam engine, and Trevithick's locomotive.

The evolution in the cooling technology for electrical, electronic and microelectronic equipment deserves a special place in the history of heat transfer. Bergles [179] presented an excellent historical review, starting from Mourmstseff's work (1935, 1942) on water and forced-air cooling of vacuum tubes. He summarized London's analysis (1954) of a 25-kW tube, Kraus' work (1965) on liquid cooling of a high-power traveling-wave tube, and other novel methods introduced by Kaye, Chu, Hwang, Simons, Kilham and Ursch, Seely, Choi, Bar-Cohen, and Steinberg.

The enhancement of convective heat transfer has a history of its own, dating from the original paper by Newton (Principia, 1687), who introduced the idea of cooling laws, later put in a mathematical form and attributed to as Newton's law of cooling. Professor Bergles takes us through this historical journey with landmarks from Fourier (1822), Joule (1861), Mollier (1897), and the founder of "modern" heat transfer, Nusselt (1915). The "roots" of the enhanced heat transfer were discovered by Professor Bergles in the early work by Whitham (1896) on introduction of retarders (now called twisted tape inserts) in fire-tube boilers, by Lea (1921) who introduced spiral fins in the tubes to agitate oil in a water-cooled oil cooler, and by the Swedish inventor Forssblad (1928) who described novel configurations for plate-fin heat exchangers. He referred to the book by Royds (1921) which gives a good picture of heat transfer technology at that time. The works by Jakob and Fritz (1931) on enhanced boiling surfaces, and Tucker and Paris (1921), and Richards on the effect of sound waves on heat transfer were also visited.

The papers written by Professor Bergles on history of heat transfer have a special place in heat transfer literature. They serve as time capsules, preserving the major developments through time, and providing a background and history to give all heat transfer practitioners a sense of belonging to this long tradition of engineering practice.

3. CLOSURE

Engineering research has many facets, including: fundamental mechanisms, methods for improvement, experimental data, and models and correlations. Professor Bergles has exhibited a mastery in these areas, combining the science and art of research. When one looks at the breadth and the depth of the work done by him, it makes his achievements even more glorious. During his continuing academic career spanning over thirty years, he undertook a number of responsibilities, most of them simultaneously, including: conducting research, writing research papers, reports, and proposals, guiding M.S. and Ph.D. students, attending conferences, preparing for invited talks and short courses, teaching undergraduate and graduate courses, welcoming visitors, and spearheading the department or the college in the administrative responsibilities. Truly, he serves as a role model for all engineers, particularly those engaged in the field of research and education. We wish him well, and look forward to his continued guidance and leadership.

4. ACKNOWLEDGMENTS

I am deeply indebted to Professor Bergles who extended untiring support in preparing this paper. He made his research papers available to me in a well-organized form, and helped me through his illuminating discussions and prompt responses.

I would like to extend a special thanks to Professor Bora B. Mikic at M.I.T. for his constant encouragement and many constructive comments. I sincerely appreciate his generous help.

5. REFERENCES

1. Bergles, A. E., and Kaye, J., 1961, "Solutions to the Heat-Conduction Equation with Time-Dependent Boundary Conditions," *Journal of Aerospace Sciences*, Vol. 28, pp. 251-252.
2. Bergles, A. E., and Rohsenow, W. M., 1962, "The Influence of Temperature Difference on the Turbulent Forced-Convection Heating of Water," *Journal of Heat Transfer*, Vol. 84, pp. 268-270.
3. Bergles, A. E., 1963, "The NML 400-Kilogauss 2-Second Pulse System," presented at the Conference on High Magnetic Fields, Their Production and Their Application, University of Oxford, Abstract Volume.
4. Bergles, A. E., and Rohsenow, W. M., 1962, "The Determination of Forced-Convection Surface-Boiling Heat Transfer," ASME Paper No. 63-HT-22, presented at 6th National Heat Transfer Conference, Boston, also in *Journal of Heat Transfer*, Vol. 86, 1964, pp. 365-372.
5. Bergles, A. E., 1963, "Subcooled Burnout in Tubes of Small Diameter," ASME Paper No. 63-WA-182, presented at ASME Winter Annual Meeting, Philadelphia.
6. Bergles, A. E., 1964, "The Influence of Flow Vibrations on Forced-Convection Heat Transfer," *Journal of Heat Transfer*, Vol. 86, pp. 559-560.
7. Daleas, R. S., and Bergles, A. E., 1965, "Effects of Upstream Compressibility on Subcooled Critical Heat Flux," ASME Paper No. 65-HT-67, presented at 8th National Heat Transfer Conference, Los Angeles.
8. Bergles, A. E., and Newell, P. H., Jr., 1965, "The Influence of Ultrasonic Vibrations on Heat Transfer to Water Flowing in Annuli," *International Journal of Heat Mass Transfer*, Vol. 8, pp. 1273-1280.
9. Bergles, A. E., and Suo, M., 1966, "Investigation of Boiling Water Flow Regimes at High Pressure," presented at Heat Transfer and Fluid Mechanics Institute, University of Santa Clara, Santa Clara, CA, *Proceedings of the 1966 Heat Transfer and Fluid Mechanics Institute*, Stanford University Press, pp. 79-99.
10. Bergles, A. E., and Scarola, L. S., 1966, "Effect of a Volatile Additive on the Critical Heat Flux for Surface Boiling of Water in Tubes," *Chemical Engineering Science*, Vol. 21, pp. 721-723.
11. Bergles, A. E., Lopina, R. F., and Fiori, M. P., 1966, "Critical-Heat-Flux and Flow-Pattern Observations for Low-Pressure Water Flowing in Tubes," ASME Paper No. 66-WA/HT-30, presented at Winter Annual Meeting, New York, 1966, also in *Journal of Heat Transfer*, Vol. 89, pp. 69-74, 1967.
12. Bergles, A. E., and Griffith, P., 1967, "Projection Slides for Classroom Demonstration of Heat Transfer with Boiling and Condensation," *Bulletin of Mechanical Engineering Education*, Vol. 6, pp. 79-83, 1967.
13. Bergles, A. E., Goldberg, P., and Maulbetsch, J. S. 1967, "Acoustic Oscillations in a High Pressure Single Channel Boiling System," presented at Symposium on Two-Phase Flow Dynamics, Eindhoven, The Netherlands, *Proceedings of the Symposium on Two-Phase Flow Dynamics*, Vol. 1, 1967, pp. 525-550, The Commission of the European Communities, Brussels.
14. Brown, W. T., Jr., and Bergles, A. E., 1968, "Measurement of Thermal Conductivity for Electrically Heated Heat Transfer Test Sections," *Proceedings of the Fourth Symposium on Thermophysical Properties*, University of Maryland, ASME, pp. 184-188.
15. Bergles, A. E., and Roos, J. P., 1968, "Film Thickness and Critical Heat Flux Observations for High Pressure Water in Spray Annular Flow," *Proceedings of the International Symposium on Research in Concurrent Gas Liquid Flow*, University of Waterloo, Plenum Press, pp. 527-559.
16. Lopina, R. F., and Bergles, A. E., 1969, "Heat Transfer and Pressure Drop in Tape Generated Swirl Flow of Single-Phase Water," ASME Paper No. 68-WA/HT-3, presented at Winter Annual Meeting, New York, 1968. Also in *Journal of Heat Transfer*, Vol. 91, pp. 434-442.
17. Bergles, A. E., 1969, "The Influence of Heated-Surface Vibration on Pool Boiling," *Journal of Heat Transfer*, Vol. 91, pp.

152-154.

18. Bergles, A. E., and Dormer, T., Jr., 1969, "Subcooled Boiling Pressure Drop with Water at Low Pressure," *International Journal of Heat Mass Transfer*, Vol. 12, pp. 459-470.

19. Bergles, A. E., 1969, "Survey and Evaluation of Techniques to Augment Convective Heat and Mass Transfer," *Progress in Heat and Mass Transfer*, Vol. 1, Pergamon Press, pp. 331-424.

20. Evans, R. G., Gouse, S. W., Jr., and Bergles, A. E., 1969, "Pressure Wave Propagation in Adiabatic Slug-Annular-Mist Two-Phase Gas-Liquid Flow," AICHE Preprint 12e, presented at the 66th National Meeting, Portland.

21. Bergles, A. E., 1969, "Electrical Probes for Study of Two-Phase Flows," presented at 11th National Heat Transfer Conference, Minneapolis. *Proceedings of the Symposium Session on Two-Phase Flow Instrumentation*, ASME, pp. 70-81.

22. Markowitz, A., and Bergles, A. E., 1969, "Heat Transfer in Spray Columns," AICHE Preprint 11, presented at 11th National Heat Transfer Conference, 1969. Also in *Chemical Engineering Progress Symposium Series* No. 102, Vol. 66, 1970, pp. 63-71.

23. Newell, P. H., Jr., and Bergles, A. E., 1969, "Analysis of Combined Free and Forced Convection for Fully-Developed Laminar Flow in Horizontal Tubes," ASME Paper No. 69-HT-39, presented at 11th National Heat Transfer Conference, Minneapolis, 1969. Also in *Journal of Heat Transfer*, Vol. 92, 1970, pp. 83-93.

24. Bergles, A. E., Lee, R. A., and Mikic, B. B., 1969, "Heat Transfer in Rough Tubes with Tape-Generated Swirl Flow," *J. Heat Transfer*, Vol. 91, pp. 443-445.

25. Fiori, M. P., and Bergles, A. E., 1969, "Photographic Study of Burnout in Flow Subcooled Boiling," color movie for ASME Heat Transfer Film Library, ASME/ESL Film Catalog Second Supplement Listing F-2.

26. Bergles, A. E., 1969, "Two-Phase Flow Structure Observations for High Pressure Water in a Rod Bundle," presented at the Symposium Session on Rod Bundle Heat Transfer, Winter Annual Meeting, Los Angeles, *Two-Phase Flow and Heat Transfer in Rod Bundles*, ASME, pp. 47-55.

27. Bergles, A. E., and Kelly, J. T., 1969, "Two-Phase Critical Flow Under Diabatic Conditions," presented at the Joint Symposium on Fluid Mechanics and Measurements in Two-Phase Systems, Leeds, England, 1969, *Proceedings of the Institution of Mechanical Engineers*, Vol. 184, Part 3C, 1969-70, pp. 127-133.

28. Thompson, W. G., Jr., and Bergles, A. E., 1970, "The Relationship of Quench Data to Steady-State Pool Boiling Data," *International Journal of Heat Mass Transfer*, Vol. 13, pp. 55-68.

29. Crowley, J. D., and Bergles, A. E., 1970, "Fluid-to-Fluid Modeling of the Hydrodynamic Stability of Flow in Boiling Channels," ASME Paper No. 70-HT-8, presented at Fluids Engineering, Heat Transfer and Lubrication Conference, Detroit.

30. Bergles, A. E., Fuller, W. D., and Hynek, S. J., 1970,

"Influence of Swirl Flow on Heat Transfer to Nitrogen in Dispersed Flow Film Boiling," Preprint J-4, presented at the Cryogenic Engineering Conference, Boulder, June 1970. Also in *Advances in Cryogenic Engineering*, Vol. 16, 1971, pp. 426-434.

31. Yadigaroglu, G., and Bergles, A. E., 1970, "Higher-Mode Density Wave Oscillations," presented at ANS 1970 Annual Meeting, Los Angeles; *Transactions of American Nuclear Society*, Vol. 13, No. 1, p. 337.

32. Evans, R. G., Gouse, S. W., Jr., and Bergles, A. E., 1970, "Pressure Wave Propagation in Adiabatic Slug-Annular-Mist Two-Phase Gas Liquid Flow," *Chemical Engineering Science*, Vol. 25, pp. 569-582.

33. Fiori, M. P., and Bergles, A. E., 1970, "Model of Critical Heat Flux in Subcooled Flow Boiling," presented at 4th International Heat Transfer Conference, Paris, September, *Heat Transfer 1970*, Vol. 6, Paper B6.3, Elsevier Publishing Company, Amsterdam.

34. Bergles, A. E., 1970, "(On) An Analysis of Laminar Combined Forced and Free Convection Heat Transfer in a Horizontal Tube," *International Journal of Heat Mass Transfer*, Vol. 13, p. 1249.

35. Bergles, A. E., and Webb R. L., 1970, "Bibliography on Augmentation of Convective Heat and Mass Transfer, presented at ASME Winter Annual Meeting, New York, *Augmentation of Convective Heat and Mass Transfer*, ASME, pp. 1-15.

36. Bergles, A. E., Brown, G. S., Jr., and Snider, W. D., 1971, "Heat Transfer Performance of Internally Finned Tubes," ASME Paper No. 71-HT-31, presented at the 12th National Heat Transfer Conference, Tulsa, August.

37. Yadigaroglu, G., and Bergles, A. E., 1971, "Fundamental and Higher-Mode Density-Wave Observations in Two-Phase Flow: The Importance of the Single-Phase Region," ASME Paper No. 71-HT-13, presented at 12th National Heat Transfer Conference, Tulsa, August.

38. Bouré, J. A., Bergles, A. E., and Tong, L. S., 1971, "Review of Two-Phase Flow Instability," ASME Paper No. 71-HT-42, presented at 12th National Heat Transfer Conference, Tulsa, August.

39. Markowitz, A., and Bergles, A. E., 1971, "Operational Limits of a Submerged Condenser," Paper 7-12, presented at International Symposium on Two-Phase Systems, Haifa, Israel, August 1971. *Progress in Heat and Mass Transfer*, Vol. 6, Pergamon Press, 1972, pp. 701-716.

40. Bergles, A. E., Fuller, W. D., and Hynek, S. J., 1971, "Dispersed Flow Film Boiling of Nitrogen with Swirl Flow," *International Journal of Heat Mass Transfer*, Vol. 14, 1971, pp. 1343-1354.

41. Bergles, A. E., and Simonds, R. R., 1971, "Combined Forced and Free Convection for Laminar Flow in Horizontal Tubes with Uniform Heat Flux," *International Journal of Heat Mass Transfer*, Vol. 14, pp. 1989-2000.

42. Bergles, A. E., 1972, "Thermal-Hydraulic Instability: Most Recent Assessments," presented at the Seminar on Two-Phase Thermohydraulics, Rome, Italy, 1972. *Termoidraulica Del Fluidi Bifase*, Comitato Nazionale Per L'Energia Nucleare, 1973, pp. 203-232.
43. Murphy, R. W., and Bergles, A. E., 1972, "Subcooled Flow Boiling of Fluorocarbons—Hysteresis and Dissolved Gas Effects on Heat Transfer," presented at Heat Transfer and Fluid Mechanics Institute, San Fernando Valley State College, Northridge, California. *Proceedings of the 1972 Heat Transfer and Fluid Mechanics Institute*, Stanford University Press, pp. 400-416.
44. Yadigaroglu, G., and Bergles, A. E., 1972, "Fundamental and Higher-Mode Density Wave Oscillations in Two-Phase Flow," *Journal of Heat Transfer*, Vol. 94, pp. 189-195.
45. Bergles, A. E., Blumenkrantz, A. R., and Taborek, J., 1972, "Performance Evaluation Criteria for Enhanced Heat Transfer Surfaces," AIChE Paper 9, presented at 13th National Heat Transfer Conference, Denver, August.
46. Chexal, V. K., and Bergles, A. E., 1972, "Two-Phase Instabilities in a Low Pressure Natural Circulation Loop," AIChE Paper 19, presented at the 13th National Heat Transfer Conference, Denver, August 1972. *AIChE Symposium Series* No. 31, Vol. 69, pp. 37-45, 1973.
47. Markowitz, A., Mikic, B. B., and Bergles, A. E., 1972, "Condensation on a Downward Facing, Horizontal Rippled Surface," ASME Paper 72-HT-33, presented at 13th National Heat Transfer Conference, Denver, August, also in *Journal of Heat Transfer*, Vol. 94, pp. 315-320.
48. Chexal, V. K., and Bergles, A. E., 1971-72, "Two-Phase Instabilities in a Low Pressure Natural Circulation Loop," 16 mm color movie produced at Georgia Tech., Atlanta, Georgia.
49. Bergles, A. E., Chu, R. C., and Seely, J. H., 1972, "Survey of Heat Transfer Techniques Applied to Electronic Equipment," IBM Technical Report TR 00.2348, August 4, ASME Paper No. 72-WA/HT-39, presented at ASME Winter Annual Meeting, New York, November.
50. Bergles, A. E., 1973, "Techniques to Augment Heat Transfer," Section 10 in *Handbook of Heat Transfer*, W. M. Rohsenow and J. P. Hartnett, Editors, McGraw-Hill Book Company, pp. 10-1 - 10-32.
51. Lopina, R. F., and Bergles, A. E., 1973, "Subcooled Boiling of Water in Tape-Generated Swirl Flow," *Journal of Heat Transfer*, Vol. 95, pp. 281-283.
52. Bergles, A. E., 1973, "Recent Developments in Convective Heat-Transfer Augmentation," *Applied Mechanics Reviews*, Vol. 26, pp. 675-682.
53. Megerlin, F. E., Murphy, R. W., and Bergles, A. E., 1973, "Augmentation of Heat Transfer in Tubes by Use of Mesh and Brush Inserts," ASME Paper 73-HT-24, presented at the 14th National Heat Transfer Conference, Atlanta, August 1973, also in *Journal of Heat Transfer*, Vol. 96, 1974, pp. 145-151.
54. Bouré, J. A., Bergles, A. E., and Tong, L. S., 1973, "Review of Two-Phase Flow Instability," *Nuclear Engineering and Design*, Vol. 25, pp. 165-192.
55. Taborek, J., Bell, K. J., Bergles, A. E., Howell J. R., Knudsen, J. G., Scabel, E. P., and Wen, C. Y., 1974, "Heat Transfer," Chapter 10 in *Annual Reviews of Industrial and Engineering Chemistry*, Vol. 2, American Chemical Society, Washington, pp. 261-295.
56. Bergles, A. E., Blumenkrantz, A. R., and Taborek, J., 1974, "Performance Evaluation Criteria for Enhanced Heat Transfer Surfaces," presented at the 5th International Heat Transfer Conference, Tokyo, Japan, September, *Heat Transfer 1974*, Vol. II, The Japan Society of Mechanical Engineers, Tokyo, pp. 234-238.
57. Hong, S. W., Morcos, S. M., and Bergles, A. E., 1974, "Analytical and Experimental Results for Combined Forced and Free Laminar Convection in Horizontal Tubes," presented at the 5th International Heat Transfer Conference, Tokyo, Japan, September, *Heat Transfer 1974*, Vol. III, The Japan Society of Mechanical Engineers, Tokyo, pp. 154-158.
58. Shelton, S., Saha, P., and Bergles, A. E., 1974, "A Study of Heat Transfer and Erosion in Internal Ballistic Devices," presented at the 11th JANNAF Combustion Meeting, Pasadena, and 11th JANNAF Combustion Meeting, Vol. 1, Chemical Propulsion Agency Publication 261, December, pp. 95-118.
59. Bergles, A. E., Bunn, R. L., and Junkhan, G. H., 1974, "Extended Performance Evaluation Criteria for Enhanced Heat Transfer Surfaces," *Letters in Heat and Mass Transfer*, Vol. 1, pp. 113-119.
60. Bergles, A. E., 1975, "Burnout in Boiling Heat Transfer, Part I: Pool-Boiling Systems," *Nuclear Safety*, Vol. 16, pp. 29-42.
61. Morcos, S. M., and Bergles, A. E., 1975, "Experimental Investigation of Combined Forced and Free Laminar Convection in Horizontal Tubes," *Journal of Heat Transfer*, Vol. 97, pp. 212-219.
62. Bergles, A. E., Junkhan, G. H., and Bunn, R. L., 1975, "Performance Criteria for Cooling System on Agricultural and Industrial Machines," preprinted for presentation at the Society of Automotive Engineers Mississippi Valley Section Spring Meeting, Dubuque, April.
63. Bergles, A. E., Junkhan, G. H., Hagge, J. K., and Jensen, M. K., 1975, "Advanced Cooling Systems for Agricultural and Industrial Machines," preprinted for presentation at the Society of Automotive Engineers Mississippi Valley Section Spring Meeting, Dubuque, April.
64. Hong, S. W., and Bergles, A. E., 1975, "Augmentation of Laminar Flow Heat Transfer in Tubes by Means of Twisted-Tape Inserts," ASME Paper 75-HT-44, presented at the 15th National Heat Transfer Conference, San Francisco, August 1975, also in *Journal of Heat Transfer*, Vol. 98, 1976, pp. 251-256.

65. Hong, S. W., and Bergles, A. E., 1976, "Laminar Flow Heat Transfer in the Entrance Region of Semi-Circular Tubes with Uniform Heat Flux," *International Journal of Heat Mass Transfer*, Vol. 7, pp. 123-124.
66. Bergles, A. E., 1976, "Survey of Augmentation of Two-Phase Heat Transfer," preprinted for presentation at ASHRAE 1976 Semiannual Meeting, Dallas, February, *ASHRAE Transactions*, Vol. 82, Part 1, pp. 891-905.
67. Royal, J. H., and Bergles, A. E., 1976, "Experimental Study of the Augmentation of Horizontal In-Tube-Condensation," preprinted for presentation at ASHRAE 1976 Semiannual Meeting, Dallas, February, *ASHRAE Transactions*, Vol. 82, Part 1, pp. 919-931.
68. Bravo, H. V., and Bergles, A. E., 1976, "Limits of Boiling Heat Transfer in a Liquid-Filled Enclosure," presented at the Heat Transfer and Fluid Mechanics Institute, University of California, Davis, June, *Proceedings of the 1976 Heat Transfer and Fluid Mechanics Institute*, Stanford University Press, pp. 114-127.
69. Hong, S. W., and Bergles, A. E., 1976, "Theoretical Solutions for Combined Forced and Free Convection in Horizontal Tubes with Temperature-Dependent Viscosity," *Journal of Heat Transfer*, Vol. 98, pp. 459-465.
70. Jensen, M. K., Cooper, P. E., and Bergles, A. E., 1976, "Boiling Heat Transfer and Dryout in Restricted Annular Geometries," AIChE Preprint 14, presented at the 16th National Heat Transfer Conference, St. Louis, August 1976. *AIChE Symposium Series*, Vol. 73, No. 164, 1977, pp. 204-213.
71. Bergles, A. E., 1976, "Review of Instabilities in Two-Phase Systems," Lecture at the NATO Advanced Study Institute on Two-Phase Flows and Heat Transfer, Istanbul, Turkey, August 1976. *Two-Phase Flows and Heat Transfer*, Vol. I, Hemisphere Publishing Corp., Washington, 1977, pp. 383-422.
72. Bergles, A. E., "Burnout in Boiling Heat Transfer, Part I: Pool Boiling Systems," Lecture at the NATO Advanced Study Institute on Two-Phase Flows and Heat Transfer, Istanbul, Turkey, August 1976. *Two-Phase Flows and Heat Transfer*, Vol. II, Hemisphere Publishing Corp., Washington, 1977, pp. 671-692.
73. Bergles, A. E., 1976, "Burnout in Boiling Heat Transfer, Part II: Subcooled and Low Quality Forced-Convection Systems," Lecture at the NATO Advanced Study Institute on Two-Phase Flows and Heat Transfer, Istanbul, Turkey, August 1976. *Two-Phase Flows and Heat Transfer*, Vol. II, Hemisphere Publishing Corp., Washington, 1977, pp. 693-720.
74. Bergles, A. E., 1976, "Survey of Augmentation of Two-Phase Heat Transfer," Lecture at the NATO Advanced Study Institute on Two-Phase Flows and Heat Transfer, Istanbul, Turkey, August 1976. *Two-Phase Flow and Heat Transfer*, Vol. II, Hemisphere Publishing Corp., Washington, 1977, pp. 817-841.
75. Bergles, A. E., Junkhan, G. H., Hagge, J. K., and Jensen, M. K., 1976, "Advanced Cooling Systems for Agricultural and Industrial Machines," S.A.E. Paper No. 751183, preprinted for S.A.E. Off-Highway Vehicle Meeting and Exhibition, Milwaukee, September.
76. Bergles, A. E., Junkhan, G. H., and Bunn, R. L., 1976, "Performance Criteria for Cooling Systems on Agricultural and Industrial Machines," S.A.E. Paper 751187, preprinted for Off-Highway Meeting and Exhibition, Milwaukee, September 1976, *S.A.E. Transactions*, 1976, Vol. 85, pp. 38-48.
77. Bergles, A. E., 1976, "Two-Phase Flow and Heat Transfer, 1756-1976," Keynote Address at the Two-Phase Flow and Heat Transfer Symposium Workshop, Fort Lauderdale, October 1976. *Two-Phase Transport and Reactor Safety*, Vol. I, Hemisphere Publishing Corp., Washington, 1978, pp. 3-28.
78. Bergles, A. E., 1976, "Survey of Augmentation of Two-Phase Heat Transfer," Invited Lecture at the Two-Phase Flow and Heat Transfer Symposium Workshop, Fort Lauderdale, October 1976, *Two-Phase Transport and Reactor Safety*, Vol. II, Hemisphere Publishing Corp., Washington, 1978, pp. 457-477.
79. Bergles, A. E., 1977, "Burnout in Boiling Heat Transfer, Part II: Subcooled and Low Quality Forced-Convection Systems," *Nuclear Safety*, Vol. 18, pp. 154-167.
80. Bergles, A. E., and Jensen, M. K., 1977, "Enhanced Single-Phase Heat Transfer for OTEC Systems," presented at the Annual OTEC Conference, New Orleans, March, *Proceedings of the 4th Annual Conference on Ocean Thermal Energy Conversion*, University of New Orleans, pp. VI-41-VI-55.
81. Bergles, A. E., Chu, R. C., and Seely, J. H., 1977, "Survey of Heat Transfer Techniques Applied to Electronic Packages," presented at the NEPCON West, Anaheim, March 1977, and NEPCON East, Philadelphia, May 1977, *Proceedings of the Technical Program National Electronic Packaging and Production Conference*, Industrial and Scientific Conference Management, Chicago, 1977, pp. 370-385.
82. Bergles, A. E., 1977, "The Evolution of Cooling Technology for Electrical Equipment and Electronic Devices," Report of Research Workshop on Directions of Heat Transfer in Electronic Equipment, Atlanta, October 1977, University of South Florida Report, 1978, pp. 4-20.
83. Hong, S. W., and Bergles, A. E., 1977, "Analysis of Combined Forced and Free Laminar Heat Transfer in the Entrance Region of Horizontal Tubes," invited paper presented at the Society of Engineering Science Annual Meeting, Lehigh University, November 1977. *Proceedings 14th Annual Meeting of the Society of Engineering Science*, Lehigh University, pp. 453-469.
84. Bergles, A. E., 1978, "Enhanced Forced Convection Heat Transfer Inside Ducts," Section 503.10, *Heat Transfer Data Book*, General Electric Co., Schenectady, New York, January.
85. Royal, J. H., and Bergles, A. E., 1978, "Augmentation of Horizontal In-Tube Condensation by Means of Twisted-Tape Inserts and Internally Finned Tubes," *Journal of Heat Transfer*, Vol. 100, pp. 17-24.

86. Bergles, A. E., and Webb, R. L., 1978, "Bibliography on Augmentation of Convection Heat and Mass Transfer Part 1," *Previews of Heat and Mass Transfer*, Vol. 4, No. 2, pp. 61-73.
87. Bergles, A. E., 1978, "Recent Trends in Experimental Heat Transfer and Fluid Mechanics," Invited Lecture at 1978 Heat Transfer and Fluid Mechanics Institute, Pullman, Washington, June 1978. *Proceedings of the 1978 Heat Transfer and Fluid Mechanics Institute*, Stanford University Press, pp. 35-38.
88. Bergles, A. E., 1978, "Augmentation of Forced-Convection Heat Transfer," Presented at the NATO Advanced Study Institute on Turbulent Forced Convection in Channels and Rod Bundles, Istanbul, Turkey, July 1978. *Turbulent Forced Convection in Channels and Bundles*, Vol. 2, Hemisphere Publishing Corp., 1979, pp. 883-909.
89. Bergles, A. E., 1978, "Enhancement of Heat Transfer," Keynote Paper presented at the Sixth International Heat Transfer Conference, Toronto, Canada, August 1978. *Heat Transfer 1978*, Vol. 6, Hemisphere Publishing Corporation, pp. 89-108.
90. Marner, W. J., and Bergles, A. E., 1978, "Augmentation of Tubeside Laminar Flow Heat Transfer by Means of Twisted-Tape Inserts, Static-Mixer Inserts and Internally Finned Tubes," presented at the Sixth International Heat Transfer Conference, Toronto, Canada, August 1978, also in *Heat Transfer 1978*, Vol. 2, Hemisphere Publishing Corporation, pp. 583-588.
91. Royal, J. H., and Bergles, A. E., 1978, "Pressure Drop and Performance Evaluation of Augmented In-Tube Condensation," presented at the Sixth International Heat Transfer Conference, Toronto, Canada, August 1978. *Heat Transfer 1978*, Vol. 2, Hemisphere Publishing Corporation, pp. 459-464.
92. Bergles, A. E., and R. L., Webb, 1978, "Bibliography on Augmentation of Convective Heat and Mass Transfer Part 2," *Previews of Heat and Mass Transfer*, Vol. 4, No. 4, pp. 89-106.
93. Bergles, A. E., Webb, R. L., and Junkhan, G. H., 1978, "Energy Conservation Via Heat Transfer Enhancement," presented at the Midwest Energy Conference, Chicago, November, 1978, also in *Energy*, Vol. 4, 1979, pp. 193-200.
94. Bergles, A. E., and Webb, R. L., 1979, "Bibliography on Augmentation of Convective Heat and Mass Transfer Part 3," *Previews of Heat and Mass Transfer*, Vol. 5, No. 2, pp. 83-103.
95. Bergles, A. E., and Webb, R. L., 1979, "Bibliography on Augmentation of Convective Heat and Mass Transfer Part 4," *Previews of Heat and Mass Transfer*, Vol. 5, No. 3, pp. 83-102.
96. Bergles, A. E., 1979, "Future Directions of Research in Multi-Phase Flow and Heat Transfer," Opening Lecture at Second Multi-Phase Flow and Heat Transfer Symposium-Workshop, Miami Beach, April 1979, *Multiphase Transport Fundamentals, Reactor Safety, Applications*, Vol. 1, Hemisphere Publishing Corporation, and McGraw-Hill International Book Company, 1980, pp. 3-18.
97. Jensen, M. K., Bergles, A. E., and Jeglic, F. A., 1979, "Effects of Oily Contaminants on Nucleate Boiling of Water," presented at the 18th National Heat Transfer Conference, San Diego, August, *AIChE Symposium Series 189*, Vol. 75, pp. 194-203.
98. Bergles, A. E., 1979, "United States Activity in Two-Phase Flow Dynamics," presented at the Japan-U.S. Seminar on Two Phase Flow Dynamics, Kobe, Japan, July 1979, *Two-Phase Flow Dynamics. Japan-U.S. Seminar 1979*, Hemisphere Publishing Corp. and McGraw-Hill International Book Co., 1981, pp. 43-58.
99. Luu, M., and Bergles, A. E., 1979, "Experimental Study of the Augmentation of In-Tube Condensation of R-113," preprinted for presentation at the ASHRAE 1979 Semiannual Meeting, Detroit, June 1979, *ASHRAE Transactions*, Vol. 85, Part 2, pp. 132-145.
100. Bergles, A. E., 1979, "Burnout in Boiling Heat Transfer. Part III: High Quality Forced Convection Systems," *Nuclear Safety*, Vol. 20, pp. 671-689.
101. Bergles, A. E., 1979, "Energy Conservation and Heat Transfer Enhancement," Keynote Lecture at International Meeting on Industrial Heat Exchangers and Heat Recovery, Liege, Belgium, November, Preprint volume, p. 275.
102. Bergles, A. E., and Webb, R. L., 1980, "Bibliography on Augmentation of Convective Heat and Mass Transfer, Part 5," *Previews of Heat and Mass Transfer*, Vol. 6, No. 1, pp. 89-106.
103. Luu, M., and Bergles, A. E., 1980, "Enhancement of Horizontal In-Tube Condensation of R-113," presented at ASHRAE Semi-Annual Meeting, Los Angeles, January 1980, *ASHRAE Transactions*, Vol. 86, Part 1, pp. 293-312.
104. Bergles, A. E., and Chyu, M. -C., 1980, "Verbesserung des Blasensiedens Durch Oberflächen mit Porösen Metallischen Überzügen," presented at Verein Deutscher Ingenieure - Gesellschaft Verfahrenstechnik und Chemieingenieurwesen, Sitzung des Fachausschusses, Wärme-und Stoff-Übertragung, Darmstadt, West Germany, April.
105. Bergles, A. E., and Webb, R. L., 1980, "Bibliography on Augmentation of Convective Heat and Mass Transfer - Part 6," *Previews of Heat and Mass Transfer*, Vol. 6, No. 3, pp. 292-313..
106. Joshi, S. D., and Bergles, A. E., 1980, "Analytical Study of Heat Transfer to Laminar In-Tube Flow of Non-Newtonian Fluids," Presented at the 19th National Heat Transfer Conference, Orlando, July 1980. *AIChE Symposium Series*, No. 199, Vol. 76, pp. 270-281.
107. Jensen, M. K., and Bergles, A. E., 1980, "Boiling Heat Transfer and Critical Heat Flux in Helical Coils," ASME Paper No. 80-HT-49 presented at the 19th National Heat Transfer Conference, Orlando, July.
108. Joshi, S. D., and Bergles, A. E., 1980, "Experimental Study of Laminar Heat Transfer to In-Tube Flow of Non-Newtonian Fluids," *Journal of Heat Transfer*, Vol. 102, pp. 397-401.
109. Bergles, A. E., 1980, "Principles of Heat Transfer Augmentation. I: Single-Phase Heat Transfer," Presented at the

NATO Advanced Study Institute on Heat Exchangers, Istanbul, 1980, Turkey, July *Heat Exchangers, Thermal Hydraulic Fundamentals and Design*, Hemisphere Publishing Corporation and McGraw-Hill International Book Company, Washington, 1981, pp. 819-842.

110. Bergles, A. E., 1980, "Principles of Heat Transfer Augmentation. II: Two-Phase Heat Transfer," Presented at the NATO Advanced Study Institute on Heat Exchangers, Istanbul, Turkey, July 1980, *Heat Exchangers, Thermal Hydraulic Fundamentals and Design*, Hemisphere Publishing Corporation and McGraw-Hill International Book Company, Washington, 1981, pp. 857-881.

111. Bergles, A. E., 1980, "Applications of Heat Transfer Augmentation," Presented at the NATO Advanced Study Institute on Heat Exchangers, Istanbul, Turkey, July 1980, *Heat Exchangers, Thermal Hydraulic Fundamentals and Design*, Hemisphere Publishing Corporation and McGraw-Hill International Book Company, Washington, 1981, pp. 883-911.

112. Bergles, A. E., 1980, "Boiling Heat Transfer Mechanisms in Reactor Thermal-Hydraulics," Presented at the ANS/ASME/NRC International Topical Meeting on Nuclear Reactor Thermal-Hydraulics, Saratoga, October 1980. Proceedings of the ANS/ASME/NRC International Topical Meeting on Nuclear Reactor Thermal-Hydraulics, NUREG/CP-0014, Vol. 2, 1980, pp. 1019-1042.

113. Joshi, S. D., and Bergles, A. E., 1980, "Survey and Evaluation of Passive Heat Transfer Augmentation Techniques for Laminar Flow," *The Journal of Thermal Engineering*, Vol. 1, pp. 105-124.

114. Luu, M., and Bergles, A. E., 1981, "Augmentation of In-Tube Condensation of R-113 by Means of Surface Roughness," presented at the ASHRAE Semiannual Meeting, Cincinnati, *ASHRAE Transactions*, Vol. 87, Part 2, pp. 33-50.

115. Bergles, A. E., 1981, "Survey of Heat Transfer Characteristics of Deep Spirally Fluted Tubing," Presented at the 20th ASME-AIChE National Heat Transfer Conference, Milwaukee, August, *Advances in Enhanced Heat Transfer - 1981*, HTD-Vol. 18, ASME, New York, pp. 21-33.

116. Bergles, A. E., and Chenoweth, J. M., 1981, "On the Presentation of Performance Data for Enhanced Tubes Used in Shell-and-Tube Heat Exchangers," W. J. Marner, Presented at the 20th ASME-AIChE National Heat Transfer Conference, Milwaukee, August, *Advances in Enhanced Heat Transfer - 1981*, HTD-Vol. 18, ASME, New York, pp. 1-10.

117. Bergles, A. E., and Chyu, M. C., 1981, "Characteristics of Nucleate Pool Boiling from Porous Metallic Coatings," Presented at the 20th ASME AIChE National Heat Transfer Conference, Milwaukee, August, *Advances in Enhanced Heat Transfer - 1981*, HTD-Vol. 18, ASME, New York, pp. 61-71.

118. Joshi, S. D., and Bergles, A. E., 1981, "Analytical Study of Laminar Flow Heat Transfer to Pseudoplastic Fluids in Tubes with

Uniform Wall Temperature," Presented at the 20th ASME-AIChE National Heat Transfer Conference, Milwaukee, August, *AIChE Symposium Series*, Vol. 77, No. 208, pp. 114-122.

119. Bergles, A. E., 1981, "Prediction of the Effects of Temperature-Dependent Fluid Properties on Laminar Heat Transfer," Presented at the NATO Advanced Study Institute on Low Reynolds Number Forced Convection in Channels and Bundles, Ankara, Turkey, July 1981. *Low Reynolds Number Flow Heat Exchangers*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1983, pp. 451-471.

120. Bergles, A. E., 1981, "Experimental Verification of Analyses and Correlation of the Effects of Temperature-Dependent Fluid Properties on Laminar Heat Transfer," presented at the NATO Advanced Study Institute on Low Reynolds Number Forced Convection in Channels and Bundles, Ankara, Turkey, July 1981. *Low Reynolds Number Flow Heat Exchangers*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1983, pp. 473-486. *Heat Exchanger Sourcebook*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1986, pp. 231-244.

121. Bergles, A. E., 1983, "Effects of Temperature-Dependent Properties on Non-Newtonian Fluids," presented at the NATO Advanced Study Institute on Low Reynolds Number Forced Convection in Channels and Bundles, Ankara, Turkey, July 1981. *Low Reynolds Number Flow Heat Exchangers*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1983, pp. 593-612. *Heat Exchanger Sourcebook*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1986, pp. 245-264.

122. Bergles, A. E., and Joshi, S. D., 1983, "Augmentation Techniques for Low Reynolds Number In-Tube Flow," Presented at the NATO Advanced Study Institute on Low Reynolds Number Forced Convection in Channels and Bundles, Ankara, Turkey, July 1981, *Low Reynolds Number Flow Heat Exchangers*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1983, pp. 695-720, *Heat Exchanger Sourcebook*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1986, pp. 619-644.

123. Webb, R. L., and Bergles, A. E., 1981, "Performance Evaluation Criteria for Selection of Heat Transfer Surface Geometries Used in Low Reynolds Number Heat Exchangers," Presented at the NATO Advanced Study Institute on Low Reynolds Number Forced Convection in Channels and Bundles, Ankara, Turkey, July 1981. *Low Reynolds Number Flow Heat Exchangers*, Hemisphere Publishing Corporation, Washington, D.C. and Springer-Verlag, Berlin, 1983, pp. 735-752.

124. Bergles, A. E., 1981, "Two-Phase Flow and Heat Transfer, 1756-1981," *Heat Transfer Engineering*, Vol. 2, Nos. 3-4, pp. 101-114.

125. Joshi, S. D., and Bergles, A. E., 1981, "Heat Transfer to

Laminar In-Tube Flow of Pseudoplastic Fluids," *AIChE Journal*, Vol. 27, pp. 872-875.

126. Jensen, M. K., and Bergles, A. E., 1981, "Critical Heat Flux in Helically Coiled Tubes," *Journal of Heat Transfer*, Vol. 103, pp. 660-666.

127. Bergles, A. E., and M. C., Chyu, 1982, "Characteristics of Nucleate Pool Boiling from Porous Metallic Coatings," *Journal of Heat Transfer*, Vol. 104, pp. 279-285.

128. Nakazatomi, M., and Bergles, A. E., 1981, "Film Evaporation Model on Horizontal Tubes," *Research Report of Ube Technical College*, No. 27, pp. 63-70.

129. Joshi, S. D., and Bergles, A. E., 1982, "Heat Transfer to Laminar Flow of Non-Newtonian Pseudoplastic Fluids in Tubes," Presented at the 7th International Heat Transfer Conference, Munich, West Germany, September, *Heat Transfer 1982*, Proceedings of the Seventh International Heat Transfer Conference, Vol. 3, Hemisphere Publishing Corporation, Washington, pp. 51-56.

130. Chyu, M. C., Bergles, A. E., and Mayinger, F., 1982, "Enhancement of Horizontal Tube Spray Film Spray Evaporators," presented at the 7th International Heat Transfer Conference, Munich, West Germany, September, *Heat Transfer 1982*, Proceedings of the Seventh International Heat Transfer Conference, Vol. 6, Hemisphere Publishing Corporation, Washington, pp. 275-280.

131. Jensen, M. K., and Bergles, A. E., 1982, "Critical Heat Flux in Helical Coils with a Circumferential Heat Flux Tilt Toward the Outside Surface," *International Journal of Heat and Mass Transfer*, Vol. 25, pp. 1383-1396.

132. Bergles, A. E., 1983, "Augmentation of Heat Transfer," *Heat Exchanger Design Handbook, Fluid Mechanics and Heat Transfer*, Vol. 2, Section 2.5.11, Hemisphere Publishing Corporation, Washington, pp. 2.5.11-1 - 12.

133. Bergles, A. E., 1983, "Augmentation of Condensation," *Heat Exchanger Design Handbook, Fluid Mechanics and Heat Transfer*, Vol. 2, Section 2.6.6, Hemisphere Publishing Corporation, Washington, pp. 2.6.6-1 - 4.

134. Bergles, A. E., 1983, "Augmentation of Boiling and Evaporation," *Heat Exchanger Design Handbook, Fluid Mechanics and Heat Transfer*, Vol. 2, Section 2.7.9, Hemisphere Publishing Corporation, Washington, pp. 2.7.9-1 - 5.

135. Bergles, A. E., 1982, "Heat Transfer Mechanisms in Nuclear Reactor Thermal-Hydraulics," Presented at the 1st Latin American Congress on Heat and Mass Transfer, La Plata, Argentina, October-November 1982, *Latin American Journal of Heat and Mass Transfer*, Vol. 8, 1984, pp. 107-129.

136. Marner, W. J., Bergles, A. E., and Chenoweth, J. M., 1983, "On the Presentation of Performance Data for Enhanced Tubes Used in Shell-and-Tube Heat Exchangers," *Journal of Heat Transfer*, Vol. 105, pp. 358-365.

137. Webb, R. L., and Bergles, A. E., 1983, "Heat Transfer

Enhancement: Second Generation Technology," *Mechanical Engineering*, Vol. 115, No. 6, pp. 60-67.

138. Junkhan, G. H., Bergles, A. E., Nirmalan, V., and Ravigururajan, T. S., 1983, "Investigation of Turbulators for Fire Tube Boilers," ASME Paper No. 83-HT-44, presented at the 21st National Heat Transfer Conference, Seattle, July.

139. Bergles, A. E., 1983, "Augmentation of In-Tube Condensation," ASHRAE Research Note 39, *ASHRAE Journal*, August, p. 46.

140. Ma, C. F., and Bergles, A. E., 1983, "Boiling Jet Impingement Cooling of Simulated Microelectronic Chips," Presented at the ASME Winter Annual Meeting, Boston, November, *Heat Transfer in Electronic Equipment*, HTD-Vol. 28, ASME, pp. 5-12.

141. Bergles, A. E., and Webb, R. L., 1984, "Heat Transfer Enhancement: Second Generation Technology," Presented at the 1984 Industrial Energy Technology Conference and Exhibition, Houston, TX, April, *Proceedings of the Sixth Annual Industrial Energy Conservation Technology Conference and Exhibition*, Vol. 1, Texas Economic Development Commission, pp. 252-260.

142. Bergles, A. E., 1984, "Enhancement of Boiling and Condensing," Presented at the China-U.S. Seminar on Two-Phase Flow and Heat Transfer, Xian, People's Republic of China, May 1984, *Two-Phase Flow and Heat Transfer: China - U.S. Progress*, Hemisphere, Washington, D.C., 1985, pp. 283-307.

143. Bergles, A. E., 1984, "Burnout in Boiling Heat Transfer: High Quality Forced-Convection Systems," Presented at the China-U.S. Seminar on Two-Phase Flow and Heat Transfer, Xian, People's Republic of China, May 1984, *Two-Phase Flow and Heat Transfer: China - U.S. Progress*, Hemisphere, Washington, D.C., 1985, pp. 177-206.

144. Bergles, A. E., 1984, "Progress in Understanding Heat Transfer in Nuclear Reactor Cooling Systems," Seminario Sobre "Transferencia de Calor y Materia en Tecnologia Nuclear," Comité Argentino de Transferencia de Calor y Materia, Buenos Aires, Argentina, July 27, Cuadernos-Transferencia de Calor y Materia en Tecnologia Nuclear, Comité Argentino de Transferencia de Calor y Materia, pp. 39-62.

145. Bergles, A. E., Nirmalan, V., and Ravigururajan, T. S., 1985, "Investigation of Turbulators for Fire Tube Boilers," G. H. Junkhan, *Journal of Heat Transfer*, Vol. 107, pp. 354-360.

146. Chyu, M.-C., and Bergles, A. E., 1985, "Falling Film Evaporation on a Horizontal Tube," Presented at the 23rd National Heat Transfer Conference, Denver, August, *Multiphase Flow and Heat Transfer*, HTD-Vol. 47, ASME, New York, pp. 39-48.

147. Marner, W. J., and Bergles, A. E., 1985, "Augmentation of Highly Viscous Laminar Tubeside Heat Transfer by Means of a Twisted-Tape Insert and an Internally Finned Tube," Presented at the 23rd National Heat Transfer Conference, Denver, August 1985. *Advances in Enhanced Heat Transfer - 1985*, HTD-Vol. 43, ASME, New York, pp. 19-28.

148. Chyu, M. C., and Bergles, A. E., 1985, "Enhancement of Horizontal Tube Spray Film Evaporators by Structured Surfaces," Presented at the 23rd National Heat Transfer Conference, Denver, August, *Advances in Enhanced Heat Transfer - 1985*, HTD-Vol. 34, ASME New York, pp. 39-48.
149. Bergles, A. E., and Webb, R. L., 1985, "A Guide to the Literature on Convective Heat Transfer Augmentation," Presented at the 23rd National Heat Transfer Conference, Denver, August 1985. *Advances in Enhanced Heat Transfer - 1985*, HTD Vol. 43, ASME, New York, pp. 81-90.
150. Park, K.-A., and Bergles, A. E., 1985, "Natural Convection Heat Transfer Characteristics of Simulated Microelectronic Chips," Presented at the 23rd National Heat Transfer Conference, Denver, August, *Heat Transfer in Electronic Equipment - 1985*, HTD-Vol. 48, ASME, New York, pp. 29-38.
151. Bergles, A. E., 1985, "Techniques to Augment Heat Transfer," Chapter 3 of *Handbook of Heat Transfer Applications*, W. M. Rohsenow, J. P. Hartnett, and E. N. Ganic, Editors, McGraw-Hill, New York, NY, pp. 3-1-3-80.
152. Ma, C.-F., Gar, Y.-P., Tang, F. J., and Bergles, A. E., 1985, "A New Method of Heat Transfer Augmentation by Means of Foreign Gas Jet Impingement in Liquid Bath," Presented at the International Symposium on Heat Transfer, Beijing, People's Republic of China, October 1985, *Heat Transfer Science and Technology*, Hemisphere Publishing Corporation, Washington, D.C., and Springer-Verlag, Berlin, 1987, pp. 789-797.
153. Bergles, A. E., 1985, "Augmented Heat Exchangers for High Temperature Applications," Presented at the International Centre for Heat and Mass Transfer XVII International Symposium on High Temperature Heat Exchangers, Dubrovnik, Yugoslavia, August 1985, *High-Temperature Heat Exchangers*, Hemisphere Publishing Corporation., Washington, D.C., and Springer-Verlag, Berlin, 1986, pp. 39-59.154.
154. Bergles, A. E., 1985, "Heat Transfer Enhancement-Application to High Temperature Heat Exchangers," Presented at the 1985 U.S.-Japan Heat Transfer Joint Seminar on Heat Transfer in High Technology and Power Engineering, San Diego, September 1985. *Heat Transfer in High Technology and Power Engineering*, Hemisphere Publishing Corporation, Washington, D.C., and Springer-Verlag, Berlin, 1987.
155. Ravigururajan, T. S., and Bergles, A. E., 1985, "General Correlations for Pressure Drop and Heat Transfer for Single-Phase Turbulent Flow in Internally Ribbed Tubes," Presented at ASME Winter Annual Meeting, Miami Beach, November, *Augmentation of Heat Transfer in Energy Systems*, HTD-Vol. 52, ASME, New York, pp. 9-20.
156. Ayub, Z. H., and Bergles, A. E., 1985, "Pool Boiling from GEWA Surfaces in Water and R-113," Presented at the ASME Winter Annual Meeting, Miami Beach, November, *Augmentation of Heat Transfer in Energy Systems*, HTD-Vol. 52, ASME, New York, pp. 57-66.
157. Bhavnani, S. H., and Bergles, A. E., 1986, "Interferometric Study of Laminar Natural Convection from an Isothermal Vertical Plate with Transverse Roughness Elements," Presented at the 8th National Heat and Mass Transfer Conference, Visakhapatnam, India, December, *Current Research in Heat and Mass Transfer*, Hemisphere Publishing Corporation, Washington, D.C., and Springer-Verlag, Berlin, pp. 1-12.
158. Baustian, J. J., Pate, M. B., and Bergles, A. E., 1986, "Properties of Oil-Refrigerant Liquid Mixtures with Applications to Oil Concentration Measurement: Part I - Thermophysical and Transport Properties," Presented at the ASHRAE Winter Meeting, San Francisco, January, *ASHRAE Transactions*, Vol. 92, Part 1A, pp. 55-73.
159. Baustian, J. J., Pate, M. B., and Bergles, A. E., 1986, "Properties of Oil-Refrigerant Liquid Mixtures with Applications to Oil Concentration Measurement: Part II - Electrical and Optical Properties," Presented at the ASHRAE Winter Meeting, San Francisco, January, *ASHRAE Transactions*, Vol. 92, Part 1A, pp. 74-92.
160. Nelson, R. M., and Bergles, A. E., 1986, "Performance Evaluation for Tubeside Heat Transfer Enhancement of a Flooded Evaporator Water Chiller," Presented at the ASHRAE Winter Meeting, San Francisco, January, *ASHRAE Transactions*, Vol. 92, Part 1B, pp. 739-755.
161. Nirmalan, V., Junkhan, G. H., and Bergles, A. E., 1986, "Investigation of the Effect of Turbulence-Producing Inserts on Heat Transfer in Tubes with Application to Fire-Tube Boilers," Presented at ASHRAE Winter Meeting, San Francisco, January, *ASHRAE Transactions*, Vol. 92, Part 1B, pp. 791-809.
162. Bergles, A. E., 1986, "The Evolution of Cooling Technology for Electrical, Electronic, and Micro-electronic Equipment," Keynote Address for Sessions on Heat Transfer in Electronic Equipment, AIAA/ASME 4th Thermophysics and Heat Transfer Conference, Boston, June 1986. *Heat Transfer in Electronic Equipment 1986*, HTD-Vol. 57, ASME, 1985, pp. 1-9. *Proceedings of the ASME/JSME Thermal Engineering Joint Conference*, Vol. 1, ASME, 1991, pp. 453-461.
163. Park, K. A., and Bergles, A. E., 1986, "Effects of Size of Simulated Microelectronic Chips on Boiling and Critical Heat Flux," Presented at the AIAA/ASME 4th Thermophysics and Heat Transfer Conference, Boston, June, *Heat Transfer in Electronic Equipment 1986*, HTD-Vol. 57, ASME, pp. 95-102.
164. Nirmalan, V., Junkhan, G. H., and Bergles, A. E., 1986, "Mechanisms of Enhancement with Turbulators for Fire-Tube Boilers," Presented at the ASHRAE 1986 Annual Meeting, Portland, OR, June, *ASHRAE Transactions*, Vol. 92, Part 2B, pp. 496-505.
165. Khanpara, J. C., Bergles, A. E., and Pate, M. P., 1986, "Augmentation of R-113 In-Tube Evaporation with Micro-Fin Tubes," Presented at the ASHRAE 1986 Annual Meeting, Portland, OR, June, *ASHRAE Transactions*, Vol. 92, Part 2B, pp.

506-524.

166. Ma, C. F., and Bergles, A. E., 1986, "Jet Impingement Nucleate Boiling," *International Journal of Heat and Mass Transfer*, Vol. 29, pp. 1095-1101.

167. L. F., Milanez, and Bergles, A. E., 1986, "Studies on Natural Convection Heat Transfer from Thermal Sources on a Vertical Surface," Presented at the 8th International Heat Transfer Conference, San Francisco, August, *Heat Transfer 1986*, Proceedings of the 8th International Heat Transfer Conference, Vol. 3, Hemisphere Publishing Corporation, Washington, D.C., pp. 1347-1352.

168. Park, K. A., and Bergles, A. E., 1986, "Boiling Heat Transfer Characteristics of Simulated Microelectronic Chips with Detachable Heat Sinks," Presented at the 8th International Heat Transfer Conference, San Francisco, August, *Heat Transfer 1986*, Proceedings of the 8th International Heat Transfer Conference, Vol. 4, Hemisphere Publishing Corporation, Washington, D.C., pp. 2099-2104.

169. Winer, W. O., Bergles, A. E., Cremers, C. J., Sabersky, R. H., Sirignano, W. A., and Westwater, J. W., 1986, "Needs in Thermal Systems," *Mechanical Engineering*, August pp. 39-46.

170. Baustian, J. J., Pate, M. B., and Bergles, A. E., 1987, "Properties of Oil-Refrigerant Liquid Mixtures with Applications to Oil Concentration Measurements," Presented at International Centre for Heat and Mass Transfer XVIII International Symposium on Heat and Mass Transfer in Cryoengineering and Refrigeration, Dubrovnik, Yugoslavia, September, *Heat and Mass Transfer in Refrigeration and Cryogenics*, Hemisphere Publishing Corporation, Washington, D.C., and Springer-Verlag, Berlin, pp. 404-428.

171. Khanpara, J. C., Bergles, A. E., and Pate, M. B., 1986, Presented "Augmentation of R-113 In-Tube Condensation with Micro-Fin Tubes," at the Winter Annual Meeting, Anaheim, CA, December, *Heat Transfer in Air Conditioning and Refrigeration Equipment*, HTD-Vol. 65, ASME, New York, pp. 21-32.

172. Ravigururajan T. S., and Bergles, A. E., 1986, "An Experimental Verification of General Correlations for Single-Phase Turbulent Flow in Ribbed Tubes," Presented at the ASME Winter Annual Meeting, Anaheim, CA, December, *Advances in Heat Exchanger Design*, HTD-Vol. 66, ASME, New York, NY, pp. 1-11.

173. Bergles, A. E., 1986, "Update to 'Recent Developments in Convective Heat-Transfer Augmentation' (AMR 26 1973: 675-682)," *Applied Mechanics Update-1986*, ASME, New York, pp. 241-245.

174. Kim C.-J., and Bergles, A. E., 1986, "Incipient Boiling Behavior of Porous Surfaces Used for Cooling of Micro-electronic Chips," Presented at the 4th Miami International Symposium on Multiphase Transport and Particulate Phenomena, Miami Beach, December 1986; *Particulate Phenomena and Multiphase Transport*, Vol. 2, Hemisphere Publishing Corporation,

Washington, D.C., and Springer-Verlag, Berlin, 1987, pp. 3-18.

175. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1987, "A Survey of Refrigerant Heat Transfer and Pressure Drop Emphasizing Oil Effects and In-Tube Augmentation," Presented at the ASHRAE Winter Meeting, New York, January, *ASHRAE Transactions*, Vol. 93, Part 1, pp. 392-416.

176. Park, K.-A., and Bergles, A. E., 1987, "Natural Convection Heat Transfer Characteristics of Simulated Microelectronic Chips," *Journal of Heat Transfer*, Vol. 109, pp. 90-96.

177. Park, K.-A., and Bergles, A. E., 1987, "Heat Transfer Characteristics of Simulated Microelectronic Chips with Heat Sinks," Presented at the International Symposium on Cooling Technology for Electronic Equipment, Honolulu, March 1987, *Cooling Technology for Electronic Equipment*, Hemisphere Publishing Corporation, Washington, D.C., 1988, pp. 353-367.

178. Bergles, A. E., 1987, "Liquid Cooling for Electronic Equipment," Keynote Lecture at International Symposium on Cooling Technology for Electronic Equipment, Honolulu, HI, March 1987. *Cooling Techniques for Computers*, Hemisphere, New York, NY, 1991, pp. 141-171.

179. Bergles, A. E., 1986, "Evolution of Cooling Technology for Electrical, Electronic, and Microelectronic Equipment," *Heat Transfer Engineering*, Vol. 7, Nos. 3-4, pp. 97-106.

180. Nirmalan, V., Junkhan, G. H., and Bergles, A. E., 1987, "A Basic Surface Renewal-Penetration Model of Heat Transfer in Tubes with Turbulators for Fire-Tube Boilers," Presented at ASHRAE Annual Meeting, Nashville, June-July, *ASHRAE Transactions*, Vol. 93, Part 2, pp. 1985-1999.

181. Ayub, Z. H., and Bergles, A. E., 1987, "Pool Boiling from GEWA Surfaces in Water and R-113," *Wärme- und Stoffübertragung*, Vol. 21, pp. 209-219.

182. Manglik, R. M., and Bergles, A. E., 1987, "A Correlation for Laminar Flow Enhanced Heat Transfer in Uniform Wall Temperature Circular Tubes with Twisted-Tape Inserts," Presented at the National Heat Transfer Conference, Pittsburgh, PA, August, *Advances in Enhanced Heat Transfer 1987*, HTD-Vol. 68, ASME, New York, pp. 35-45.

183. Khanpara, J. C., Bergles, A. E., and M. B., Pate, 1987, "A Comparison of In-Tube Evaporation of Refrigerant 113 in Electrically Heated and Fluid Heated Smooth and Inner-Fin Tubes," Presented at the National Heat Transfer Conference, Pittsburgh, PA, August, *Advances in Enhanced Heat Transfer 1987*, HTD-Vol. 68 ASME, New York, pp. 35-45.

184. Chyu, M. C., and Bergles, A. E., 1987, "Thermal Analysis on the Electric Cylindrical Test Heater for Heat Transfer Experiments," ASME Paper No. 87-HT-44 Presented at National Heat Transfer Conference, Pittsburgh, PA, August.

185. Reid, R. S., Pate, M. B., and Bergles, A. E., 1987, "Evaporation of R-113 Refrigerant Flowing Inside Smooth Tubes," ASME Paper No. 87-HT-51, Presented at National Heat Transfer Conference, Pittsburgh, PA, August.

186. Bergles, A. E., 1989, "Enhancement of Convective Heat Transfer - Newton's Legacy Pursued," Presented at the Polish Society of Theoretical and Applied Mechanics Session on 300th Anniversary of Newton's *Principia*, Szczyrk, Poland, October, *Mechanika Teoretyczna i Stosowana*, Vol. 27, pp. 381-394.
187. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1987, "Wärmetübertragung und Druckabfall beim Verdampfen und Kondensieren von R22 in Horizontalen Micro-Fin-Rohren," Presented at DKV Tagung, Cologne, West Germany, November, *Bericht über die Kälte-Klima-Tagung 1987 des Deutschen Kälte-und Klimatechnischen Vereins*, Kessler Schnelldruck, Stuttgart, pp. 361-377.
188. Bergles, A. E., 1987, "Fundamentals of Boiling and Evaporation," Presented at NATO ASI on Thermal-Hydraulic Fundamentals and Design of Two-Phase Flow Heat Exchangers, Pova de Varzim, Portugal, July 1987. *Two-Phase Flow Heat Exchangers. Thermal-Hydraulic Fundamentals and Design*, Kluwer Academic Publishers, Dordrecht, The Netherlands, 1988, pp. 159-200.
189. Bergles, A. E., 1987, "Heat Transfer Augmentation," Presented at the NATO ASI on Thermal-Hydraulic Fundamentals and Design of Two-Phase Flow Heat Exchangers, Pova de Varzim, Portugal, July 1987. *Two-Phase Flow Heat Exchangers. Thermal-Hydraulic Fundamentals and Design*, Kluwer Academic Publishers, Dordrecht, The Netherlands, 1988, pp. 343-373.
190. Chyu, M.-C., and Bergles, A. E., 1987, "An Analytical and Experimental Study of Falling-Film Evaporation on a Horizontal Tube," *Journal of Heat Transfer*, Vol. 109, pp. 983-990.
191. Reid, R. S., Pate, M. B., and Bergles, A. E., 1987, "A Comparison of Augmentation Techniques During In-Tube Evaporation of R-113," Presented (poster) at the ASME Winter Annual Meeting, Boston, December, *Boiling and Condensation in Heat Transfer Equipment*, HTD-Vol. 85, ASME, New York, pp. 21-30.
192. Khanpara, J. C., Pate, M. B., and Bergles, A. E., 1987, "Local Evaporation Heat Transfer in a Smooth Tube and a Micro-Fin Tube Using Refrigerants 22 and 113," Presented (poster) at the ASME Winter Annual Meeting, Boston, December, *Boiling and Condensation in Heat Transfer Equipment*, HTD-Vol. 85, ASME, New York, pp. 31-40.
193. Ravigurajan, T. S., and Bergles, A. E., 1987, "An Overview of Thermal Hydraulic Correlations for Internal Flow in Rough Tubes," Presented at the 8th Miami International Conference on Alternative Energy Sources, Miami Beach, FL, December, Abstract Volume 2, pp. 427-429.
194. Ravigurajan, T. S., and Bergles, A. E., 1987, "Optimization of Enhanced Heat Exchangers Including OTEC Evaporators and Condensers," Presented at the 8th Miami International Conference on Alternative Energy Sources, Miami Beach, FL, December 1987, Abstract Volume 1, pp. 192-193. *Alternative Energy Sources VIII*, Vol. 1, Hemisphere, New York, 1989, pp. 1031-1050.
195. Park, K. A., and Bergles, A. E., 1987, "The Critical Heat Flux for Horizontal Cylindrical Heaters," *Energy R&D*, (Korean Institute of Energy and Resources), Vol. 9, No. 4, pp. 16-26.
196. Ayub, Z. H., and Bergles, A. E., 1988, "Pool Boiling Enhancement of a Modified GEWA-T Surface in Water," *Journal of Heat Transfer*, Vol. 110, pp. 266-268.
197. Chyu M.-C., and Bergles, A. E., 1988, "Thermal Analysis of the Electrically Heated Cylindrical Test Section for Heat Transfer Experiments," *Experimental Thermal and Fluid Science*, Vol. 1, pp. 19-27.
198. Manglik, R. M., and Bergles, A. E., 1988, "Laminar Flow Heat Transfer in a Semi-Circular Tube with Uniform Wall Temperature," *International Journal of Heat and Mass Transfer*, Vol. 31, pp. 625-636.
199. Park, K. -A., and Bergles, A. E., 1988, "Ultrasonic Enhancement of Saturated and Subcooled Pool Boiling," *International Journal of Heat and Mass Transfer*, Vol. 31, pp. 664-667.
200. Bergles, A. E., 1988, "High Flux Boiling Applied to Microelectronics Thermal Control," Presented at The James W. Westwater Symposium on Boiling and Condensation, University of Illinois, Urbana, May 6, *International Communications in Heat and Mass Transfer*, Vol. 15, pp. 509-531.
201. Park, K. -A., and Bergles, A. E., 1988, "Effects of Size of Simulated Microelectronic Chips on Boiling and Critical Heat Flux," *Journal of Heat Transfer*, Vol. 110, pp. 728-734.
202. Bergles, A. E., and Kim, C. -J., 1988, "A Method to Reduce Temperature Overshoots in Immersion Cooling of Electronic Devices," Presented at the InterSociety Conference on Thermal Phenomena in the Fabrication and Operation of Electronic Components, May, *Proceedings of the InterSociety Conference on Thermal Phenomena in the Fabrication and Operation of Electronic Components*, IEEE, New York, pp. 100-105.
203. Tien, Y. C., Ma, C. F., Lee, S. C., La, D. H., and Bergles, A. E., 1988, "Enhanced Heat Transfer from Simulated Microchips to Surrounding Liquid of Low Volatility with Gas Jet Impingement," Presented at the International Symposium on Phase Change Heat Transfer, Chongqing, China, May, *Advances in Phase Change Heat Transfer*, International Academic Publishers, Beijing, and Chongqing University Press, Chongqing, pp. 419-424.
204. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1988, "Evaporation and Condensation of Refrigerant-Oil Mixtures in a Low-Fin Tube," Presented at ASHRAE Annual Meeting, Ottawa, Canada, June, *ASHRAE Transactions*, Vol. 94, Part 2, pp. 1176-1194.
205. Junkhan, G. H., Bergles, A. E., Nirmalan, V., and Hanno, W., 1988, "Performance Evaluation of the Effects of a Group of Turbulator Inserts on Heat Transfer from Gases in Tubes,"

Presented at ASHRAE Annual Meeting, Ottawa, Canada, June, *ASHRAE Transactions*, Vol. 94, Part 2, pp. 1195-1212.

206. Baustian, J. J., M. B., Pate, and Bergles, A. E., 1988, "Measuring the Concentration of a Flowing Oil-Refrigerant Mixture with a Vibrating U-Tube Densimeter," Presented at ASHRAE Annual Meeting, Ottawa, Canada, June, *ASHRAE Transactions*, Vol. 94, Part 2, pp. 571-587.

207. Baustian, J. J., Pate, M. B., and Bergles, A. E., 1988, "Measuring the Concentration of a Flowing Oil-Refrigerant Mixture with a Bypass Viscometer," Presented at ASHRAE Annual Meeting, Ottawa, Canada, June, *ASHRAE Transactions*, Vol. 94, Part 2, pp. 588-601.

208. Baustian, J. J., Pate, M. B., and Bergles, A. E., 1988, "Measuring the Concentration of a Flowing Oil-Refrigerant Mixture with an Acoustic Velocity Sensor," Presented at ASHRAE Annual Meeting, Ottawa, Canada, June, *ASHRAE Transactions*, Vol. 94, Part 2, pp. 602-615.

209. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1988, "Evaporation and Condensation of Refrigerant-Oil Mixtures in a Smooth Tube and a Micro-Fin Tube," Presented at ASHRAE Winter Meeting, Dallas, January, *ASHRAE Transactions*, Vol. 94, Part 1, pp. 149-166.

210. Baustian, J. J., Pate, M. B., and Bergles, A. E., 1988, "Measuring the Concentration of a Flowing Oil-Refrigerant Mixture: Instrument Test Facility and Initial Results," Presented at ASHRAE Winter Meeting, Dallas, January, *ASHRAE Transactions*, Vol. 94, Part 1, pp. 167-177.

211. Bergles, A. E., 1988, "Enhancement of Convective Heat Transfer: Newton's Legacy Pursued," Presented at 25th National Heat Transfer Conference, Houston, August, *History of Heat Transfer*, ASME, New York, pp. 53-64.

212. Rabas, T. J., Bergles, A. E., and Moen, D. L., 1988, "Heat Transfer and Pressure Drop Correlations for Spirally Grooved (Rope) Tubes Used in Surface Condensers and Multistage Flash Evaporators," Presented (poster) at 25th National Heat Transfer Conference, Houston, August, *ASME Proceedings of the 1988 National Heat Transfer Conference*, Vol. 1, HTD-Vol. 96, ASME, New York, pp. 693-704.

213. Bhavnani, S. H., and Bergles, A. E., 1988, "An Experimental Study of Laminar Natural Convection Heat Transfer from Wavy Surfaces," Presented (poster) at 25th National Heat Transfer Conference, Houston, August, *ASME Proceedings of the 1988 National Heat Transfer Conference*, Vol. 2, HTD-Vol. 96, ASME, New York, pp. 173-180.

214. Ayub, Z. H., and Bergles, A. E., 1988, "Nucleate Pool Boiling Curve Hysteresis for GEWA-T Surfaces in Saturated R-113," Presented (poster) at 25th National Heat Transfer Conference, Houston, August, *ASME Proceedings of the 1988 National Heat Transfer Conference*, Vol. 2, HTD-Vol. 96, ASME, New York, pp. 515-521.

215. Bergles, A. E., 1988, "The Impact of Heat Transfer

Enhancement on Energy Conservation; The Current Status of Heat Transfer Enhancement," Keynote Address at International Symposium on Heat Transfer Enhancement and Energy Conservation, Quanzhou, China, August, *Heat Transfer Enhancement and Energy Conservation*, Hemisphere, New York, 1990, pp. 11-48.

216. Ma, C. F., Tian, Y. Q., Sun, H., Lei, D. H., and Bergles, A. E., 1988, "Local Characteristics of Heat Transfer from a Small Heater to an Impinging Round Jet of Liquid of Larger Pr Number," Presented at International Symposium on Heat Transfer Enhancement and Energy Conservation, Quanzhou, China, August 1988, *Heat Transfer Enhancement and Energy Conservation*, Hemisphere, New York, 1990, pp. 223-229.

217. Ma C. F., and Bergles, A. E., "Convective Heat Transfer on a Small Vertical Heated Surface in an Impinging Circular Liquid Jet," Presented at Second International Symposium on Heat Transfer, Beijing, China, August 1988. Preprints, Vol. 1, pp. 248-255, 1988, *Heat Transfer Science and Technology*, Hemisphere, New York, 1989, pp.

218. Bergles, A. E., 1988, "Cooling Electronic Equipment: Past, Present, and Future," W. Nakayama and Keynote Lecture at International Centre for Heat and Mass Transfer XX International Symposium on Heat Transfer in Electronic and Microelectronic Equipment, Dubrovnik, Yugoslavia, August 1988, *Heat Transfer in Electronic and Microelectronic Equipment*, Hemisphere, New York, pp. 3-39, 1990. "Hladenje Elektronske Opreme: Juce, Danas, Sutra," *Termotehnika*, Vol. 15, 1989, pp. 237-269. *Bulletin of the International Centre for Heat and Mass Transfer*, Vol. 4, 1990, pp. 1-37.

219. Ma, C. F., and Bergles, A. E., 1988, "Enhancement of Immersion Cooling of Microelectronic Devices by Gas Jet Impingement," Presented at International Centre for Heat and Mass Transfer XX International Symposium on Heat Transfer in Electronic and Microelectronic Equipment, Dubrovnik, Yugoslavia, August 1988, *Heat Transfer in Electronic and Microelectronic Equipment*, Hemisphere, New York, pp. 537-549.

220. Park, K.-A., Bergles, A. E., and Danielson, R. D., 1988, "Boiling Heat Transfer Characteristics of Simulated Microelectronic Chips with Fluorinert Liquids," Presented at International Centre for Heat and Mass Transfer Symposium on Heat Transfer in Electronic and Microelectronic Equipment, Dubrovnik, Yugoslavia, August 1988, *Heat Transfer in Electronic and Microelectronic Equipment*, Hemisphere, New York, 1990, pp. 573-588.

221. Bergles, A. E., 1988, "The Role of Experimentation in Thermo-Fluid Sciences," Plenary Lecture at First World Conference on Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics, Dubrovnik, Yugoslavia, September 1988. *Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics 1988*, Elsevier Science Publishing Co., New

- York, 1988, pp. 1-12, *Experimental Thermal and Fluid Science*, Vol. 3, 1990, pp. 2-13.
222. Manglik, R. M., Bergles, A. E., and Joshi, S. D., 1988, "Augmentation of Heat Transfer to Laminar Flow of Non-Newtonian Fluids, in Uniformly Heated Tubes with Twisted-Tape Inserts," Presented at First World Conference on Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics, Dubrovnik, Yugoslavia, September, *Experimental Heat Transfer, Fluid Mechanics, and Thermodynamics 1988*, Elsevier Science Publishing Co., New York, pp. 676-684.
223. Bergles, A. E., 1988, "Some Perspectives on Enhanced Heat Transfer - Second-Generation Heat Transfer Technology," *Journal of Heat Transfer*, Vol. 110, No. 4(B), 1082-1096.
224. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1989, "A Comparison of 150 and 300 SUS Oil Effects on Refrigerant Evaporation and Condensation in a Smooth Tube and a Micro-fin Tube," Presented at ASHRAE Winter Meeting, Chicago, January, *ASHRAE Transactions*, Vol. 95, Part 1, pp. 387-397.
225. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1989, "Heat Transfer and Pressure Drop During Evaporation and Condensation of R22 in Horizontal Micro-fin Tubes," *International Journal of Refrigeration*, Vol. 12, pp. 6-14.
226. Manglik R. M., and Bergles, A. E., 1989, "The Thermal-Hydraulic Design of the Rectangular Offset-Strip-Fin Compact Heat Exchanger," Presented at A. L. London Symposium on Compact Heat Exchangers, Stanford, March 1989, *Compact Heat Exchangers*, Hemisphere, New York, 1990, pp. 123-149.
227. Chyu M. -C., and Bergles, A. E., 1989, "Locating Method for Temperature-Sensing Elements Inserted in Solid Bodies," *Experimental Thermal and Fluid Science*, Vol. 2, pp. 247-249.
228. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1989, "Heat Transfer and Pressure Drop Performance of Smooth and Internally Finned Tubes with Oil and Refrigerant 22 Mixtures," Presented at ASHRAE Annual Meeting, Vancouver, June, *ASHRAE Transactions*, Vol. 95, Part 2, pp. 375-385.
229. Bergles, A. E., 1989, "The Challenge of Enhanced Heat Transfer with Phase Change," Presented at VII Congresso Nazionale sulla Trasmissione del Calore, Florence, Italy, June, *Proceedings VII Congresso Nazionale sulla Trasmissione del Calore*, Societa Editrice Esculapio, Bologna, Italy, pp. 1-12.
230. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1989, "Evaporation and Condensation Heat Transfer and Pressure Drop in Horizontal 12.7-mm Micro-Fin Tubes with Refrigerant 22," Presented (poster) at 26th National Heat Transfer Conference and Exhibition, Philadelphia, August 1989, *Heat Transfer Equipment Fundamentals, Design, Applications, and Operating Problems*, HTD-Vol. 108, ASME, New York, pp. 205-214, 1989, *Journal of Heat Transfer*, Vol. 112, 1990, pp. 1041-1047.
231. Marner, W. J., and Bergles, A. E., 1989, "Augmentation of Highly Viscous Laminar Heat Transfer Inside Tubes with Constant Wall Temperature," *Experimental Thermal and Fluid Science*, Vol. 2, pp. 252-267.
232. Chyu, M. C., and Bergles, A. E., 1989, "Horizontal-Tube Falling-Film Evaporation with Structured Surfaces," *Journal of Heat Transfer*, Vol. 111, pp. 518-524.
233. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1989, "Performance of Micro-fin Tubes with Refrigerant-22 and Oil Mixtures," *ASHRAE Journal*, Vol. 31, pp. 17-28.
234. Bergles, A. E., Kim, C. -J., Verhoeven, J. D., and Gibson, E. D., 1989, "A Novel Enhanced Boiling Heat Sink for Immersion Cooling of Microelectronic Devices," Presented at VIIIth Symposium on Heat Transfer, Warsaw, Jadwisin, Poland, October, *Referaty VII Sympozjum Wymiany Ciepła i Masy*, Polska Akademia Nauk, Komitet Termodynamiki i Spalania, Warsaw-Jadwisin, Poland, pp. 8-16.
235. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1990, "Performance Predictions of Refrigerant-Oil Mixtures in Smooth and Internally Finned Tubes - Part I: Literature Review," Presented at 1990 Winter Meeting, Atlanta, February, *ASHRAE Transactions*, Vol. 96, Part 1, pp. 160-169.
236. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1990, "Performance Predictions of Refrigerant-Oil Mixtures in Smooth and Internally Finned Tubes - Part II: Design Equations," L. M. Schlager, M. B. Pate, and Bergles, A. E., Presented at 1990 Winter Meeting, Atlanta, February, *ASHRAE Transactions*, Vol. 96, Part II, pp. 170-182.
237. Ayub Z. H., and Bergles, A. E., 1990, "Nucleate Pool Boiling Curve Hysteresis for GEWA-T Surfaces in Saturated R-113," *Experimental Thermal and Fluid Science*, Vol. 3, pp. 249-255.
238. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1990, "Condensation of Refrigerant-Oil Mixtures in Smooth and Augmented Tubes," Presented at Second International Symposium on Condensers and Condensation, Bath, UK, March, *Condensers and Condensation*, HTFS, Harwell, UK, pp. 451-460.
239. Bhavnani, S. H., and Bergles, A. E., 1990, "Effect of Surface Geometry and Orientation on Laminar Natural Convection Heat Transfer from a Vertical Flat Plate with Transverse Roughness Elements," *International Journal of Heat and Mass Transfer*, Vol. 33, pp. 965-981.
240. Bergles, A. E., 1990, "Transport Process in a Rapidly Changing World," Presented at NATO Advanced Study Institute on Convective Heat and Mass Transfer in Porous Media, Cesme, Turkey, August, *Convective Heat and Mass Transfer in Porous Media*, Kluwer Academic Publishers, Dordrecht, The Netherlands, pp. 1-4.
241. Vandervort, C. L., Bergles, A. E., and Jensen, M. K., 1990, "Ultimate Limits of Boiling Heat Fluxes," Presented at 8th Symposium of Energy Engineering Sciences, Argonne, May,

Proceedings of the 8th Symposium of Energy Engineering Sciences: Micro/Macro Studies of Multiphase Media, Argonne, IL, CONF-9001583, pp. 95-102.

242. Manwell, S. P., and Bergles, A. E., 1990, "Gas-Liquid Flow Patterns in Refrigerant-Oil Mixtures," Presented at ASHRAE Annual Meeting, St. Louis, June, *ASHRAE Transactions*, Vol. 96, Part 2, pp. 456-464.

243. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1990, "Oil Quantity Measurements in Smooth and Micro-Fin Tubes During Evaporation and Condensation of Refrigerant-Oil Mixtures," Presented at ASHRAE Annual Meeting, St. Louis, June, *ASHRAE Transactions*, Vol. 96, Part 2, pp. 465-469. 244.

244. Borkowski, C. A., Jensen, M. K., and Bergles, A. E., 1989, "The Computer as an Aid to Teaching Experimentation: An Example in the Thermal Sciences," Presented at 1989 Frontiers in Education Conference, Binghamton, October, *Proceedings of the 1989 Frontiers in Education Conference*, IEEE, New York, pp. 93-104.

245. Carvalho, R. D. M., and Bergles, A. E., 1990, "The Influence of Subcooling on the Pool Nucleate Boiling and Critical Heat Flux of Simulated Electronic Chips," Presented (poster) at Ninth International Heat Transfer Conference, Jerusalem, Israel, August, *Proceedings of the Ninth International Heat Transfer Conference*, Vol. 2, Hemisphere, New York, pp. 289-294.

246. Armstrong, R. D., and Bergles, A. E., 1990, "A Study of Enhanced Ceramic Tubes for High Temperature Waste Heat Recovery," Presented (poster) at Ninth International Heat Transfer Conference, Jerusalem, Israel, August, *Proceedings of the Ninth International Heat Transfer Conference*, Vol. 4, Hemisphere, New York, pp. 21-26.

247. Bergles, A. E., 1990, "The Challenge of International Cooperation in Heat and Mass Transfer," banquet speech at 6th Miami International Symposium on Heat and Mass Transfer, Miami, December 1990, *Heat and Mass Transfer: An Era of Change*, Vol. 1, Nova Science Publishers, Commack, NY, 1994.

248. Schlager, L. M., Pate, M. B., and Bergles, A. E., 1990, "The Effect of Heater Thermal Properties and Thickness on the Pool Boiling Critical Heat Flux," Presented at III Encontro Nacional de Ciencias Termicas, Itaperna, Brazil, December, *Proceedings of the 3rd Brazilian Thermal Sciences Meeting (III ENCIT)*, Vol. II, pp. 577-582.

249. Reid, R. S., Pate, M. B., and Bergles, A. E., 1991, "A Comparison of Augmentation Techniques During In-Tube Evaporation of R-113," *Journal of Heat Transfer*, Vol. 113, pp. 451-458.

250. Somerscales, E. F. C., Ponteduro, A. F., and Bergles, A. E., 1991, "Particulate Fouling of Heat Transfer Tubes Enhanced on Their Inner Surface," Presented at the 27th National Heat Transfer Conference and Exposition, Minneapolis, July, *Fouling and Enhancement Interactions*, HTD-Vol. 164, ASME, New York, pp. 17-28.

251. Ravigurajan, T. S., and Bergles, A. E., 1991, "Visualization of Flow Phenomena Near Enhanced Surfaces," Presented at the 27th National Heat Transfer and Exposition, Minneapolis, July, *Fouling and Enhancement Interactions*, HTD-Vol. 164, ASME, New York, pp. 71-75.

252. Bhavnani, S. H., and Bergles, A. E., 1991, "Natural Convection Heat Transfer from Sinusoidal Wavy Surfaces," *Wärme- und Stoffübertragung*, Vol. 26, pp. 341-349.

253. Bonetto, F., Clausse, A., Converti, J., Carvalho, R. D. M., and Bergles, A. E., 1991, "Probabilistic Interpretation of the Experimental Indicator Function in Two Phase Flow," *Proceedings of the International Conference on Multiphase Flow '91 Tsukuba*, University of Tsukuba, Tsukuba, Japan, Vol. 2, pp. 598-601.

254. Carvalho, R. D. M., and Bergles, A. E., 1991, "The Use of Hot Wire Anemometry for Local Void Fraction Measurements in Pool Boiling," Presented (poster) at XI Congresso Brasileiro de Engenharia Mecanica, Sao Paulo, Brazil, December, *Proceedings 11th ABCM Mechanical Engineering Conference*, Associacao Brasileira de Ciencias Mecanicas, Vol. 1, pp. 279-282.

255. Bergles, A. E., 1991, "Heat Transfer Enhancement - Second Generation Heat Transfer Technology," Presented at XI Congresso Brasileiro de Engenharia Mecanica, Sao Paulo, Brazil, December 1991. Preprinted for Congress, *Latin American Applied Research*, Vol. 23, 1993, pp. 141-152.

256. Bergles, A. E., 1991, "Computer (Cooling)," *McGraw-Hill Yearbook of Science and Technology, 1992*, McGraw-Hill, New York, 1991, pp. 83-85.

257. Bergles, A. E., 1992, "What is the Real Mechanism of CHF in Pool Boiling?," Presented at Engineering Foundation Conference on Pool and External Flow Boiling, Santa Barbara, CA, March, *Pool and External Flow Boiling*, ASME, New York, NY, pp. 165-170.

258. Jensen, M. K., Trewin, R. R., and Bergles, A. E., 1992, "Crossflow Boiling in Enhanced Tube Bundles," Presented at Engineering Foundation Conference on Pool and External Flow Boiling, Santa Barbara, CA, March, *Pool and External Flow Boiling*, ASME, New York, NY, pp. 373-379.

259. Carvalho, R. D. M., and Bergles, A. E., 1992, "The Effects of Heater Thermal Conductance/Capacitance on the Pool Boiling Critical Heat Flux," Presented at Engineering Foundation Conference on Pool and External Flow, Boiling, Santa Barbara, CA, March, *Pool and External Flow Boiling*, ASME, New York, NY, pp. 203-211.

260. Golobic, I., and Bergles, A. E., 1992, "Effects of Thermal Properties and Thickness of Horizontal Vertically Oriented Ribbon Heaters on the Pool Boiling Critical Heat Flux," Presented at Engineering Foundation Conference on Pool and External Flow Boiling, Santa Barbara, CA, March, *Pool and External Flow Boiling*, ASME, New York, NY, pp. 213-218.

261. Manglik, R. M., and Bergles, A. E., 1992, "Heat Transfer

Enhancement and Pressure Drop in Viscous Liquid Flows in Isothermal Tubes with Twisted-Tape Inserts," *Wärme- und Stoffübertragung*, Vol. 27, pp. 249-257.

262. Bergles, A. E., and Bar-Cohen, A., 1990, "Direct Liquid Cooling of Microelectronic Components," *Advances in Thermal Modeling of Electronic Components and Systems*, ASME Press, New York, NY, pp. 233-342.

263. Bergles, A. E., 1992, "Enhanced Heat Transfer Techniques for High-Heat-Flux Boiling," Presented (poster) at SPIE Symposium, San Diego, CA, July, Conference on High Heat Flux Engineering, *SPIE Proceedings*, The International Society for Optical Engineering, Bellingham, WA, Vol. 1739, pp. 2-17.

264. Manglik, R. M., and Bergles, A. E., 1992, "Heat Transfer and Pressure Drop Correlations for Twisted-Tape Inserts in Isothermal Tubes: Part I, Laminar Flows," Presented at National Heat Transfer Conference, San Diego, August 1992. *Enhanced Heat Transfer*, HTD-Vol. 202, ASME, New York, 1992, pp. 89-98, *Journal of Heat Transfer*, Vol. 115, 1993, pp. 881-889.

265. Manglik, R. M., and Bergles, A. E., 1992, "Heat Transfer and Pressure Drop Correlations for Twisted-Tape Inserts in Isothermal Tubes: Part II, Transition and Turbulent Flows," Presented at National Heat Transfer Conference, San Diego, August 1992. *Enhanced Heat Transfer*, HTD-Vol. 202, ASME, New York, 1992, pp. 99-106. *Journal of Heat Transfer*, Vol. 115, 1993, pp. 890-896.

266. Vandervort, C. L., Bergles, A. E., and Jensen, M. K., 1992, "Heat Transfer Mechanisms in Very High Heat Flux Subcooled Boiling," Presented at Winter Annual Meeting, ASME, Anaheim, CA, November, *Fundamentals of Subcooled Boiling*, HTD-Vol. 217, ASME, New York, New York, pp. 1-10.

267. Jensen, M. K., Trewin, R. R., and Bergles, A. E., 1992, "Crossflow Boiling in Enhanced Tube Bundles," Presented at Winter Annual Meeting, ASME, Anaheim, CA, November, *Two-Phase Flow in Energy Systems*, HTD-Vol. 220, pp. 11-17.

268. Ravigururajan, T. S., and Bergles, A. E., 1992, "Heat Transfer Enhancement of In-Tube Flow of Water at Low Temperatures," Presented (poster) as paper 92-WA/HT-3 at Winter Annual Meeting, ASME, Anaheim, CA, November.

269. Bergles, A. E., 1992, "Elements of Boiling Heat Transfer," *Boiling Heat Transfer - Modern Developments and Advances*, Elsevier Science Publishers, Amsterdam, The Netherlands, pp. 389-445.

270. Ha, S., and Bergles, A. E., 1993, "The Influence of Oil on Local Evaporation Heat Transfer Inside a Horizontal Micro-fin Tube," Presented at ASHRAE Winter Meeting, Chicago, January, *ASHRAE Transactions*, Vol. 99, Part 1, pp. 1244-1255.

271. Ha, S., and Bergles, A. E., 1993, "Local Heat Transfer Characteristics of Horizontal In-tube Evaporation," Presented at 6th International Symposium on Transport Phenomena (ISTP-6) in Thermal Engineering, Seoul, Korea, May, *Transport Phenomena in Thermal Engineering*, Vol. 2, Begell House, New

York, pp. 902-909.

272. Bergles, A. E., and Bar-Cohen, A., 1993, "Immersion Cooling of Digital Computers," Presented at the NATO Advanced Study Institute on Cooling of Electronic Systems, Cesme, Turkey, June 1993. *Cooling of Electronic Systems*, Kluwer Academic Publishers, Dordrecht, The Netherlands, 1994, pp. 539-621.

273. Bergles, A. E., 1993, "The Effect of Fouling on Enhanced Heat Transfer Equipment," Presented at ICHMT International Symposium on New Developments in Heat Exchangers, Lisbon, Portugal, September, Preprinted for Symposium.

274. Zitz, J. A., and Bergles, A. E., 1993, "Immersion Cooling of a Multichip Module by Pool Boiling of FC-86," Presented at International Electronics Packaging Conference, Binghamton, NY, October, *Advances in Electronic Packaging 1993*, Vol. 2, ASME, New York, pp. 917-926.

275. Manglik, R. M., and Bergles, A. E., 1993, "Numerical Predictions of Fully Developed Laminar Flows in Circular Segments Ducts," Presented (poster) at ASME Winter Annual Meeting, New Orleans, LA, December, *General Papers on Convection*, HTD-Vol. 256, ASME, New York, NY, pp. 9-19.

276. Bergles, A. E., 1992, "Heat Transfer Enhancement - Second Generation Heat Transfer Technology," Presented at X Congresso Nazionale Sulla Trasmissione del Calore, Genova, Italy, June, *Proceedings X Congresso Nazionale Sulla Trasmissione del Calore*, Universita degli Studi di Genova, Genova, Italy, pp. 3-21.

277. Manglik, R. M., and Bergles, A. E., 1994, "Influence of Twisted Tape Generated Swirl on Single-Phase Heat Transfer," Presented (poster) at First ISHMT-ASME Heat and Mass Transfer Conference and Twelfth National Heat and Mass Transfer Conference, Bombay, India, January, *Heat and Mass Transfer 94*, Tata McGraw-Hill, New Delhi, India, pp. 249-256.

278. Bergles, A. E., 1994, "The Influence of Fouling on Enhanced Heat Transfer," Presented at International Symposium/Workshop on Boiling, Condensation and Two-Phase Heat Transfer, Visakhapatnam, India, January. Preprinted for Symposium/Workshop.

279. Ravigururajan, T. S., and Bergles, A. E., 1994, "Visualization of Flow Phenomena Near Enhanced Surfaces," *Journal of Heat Transfer*, Vol. 116, pp. 54-57.

280. Vandervort, C. L., Bergles, A. E., and Jensen, M. K., 1994, "An Experimental Study of Critical Heat Flux in Very High Heat Flux Subcooled Boiling," *International Journal of Heat and Mass Transfer*, Vol. 37, suppl. 1, pp. 161-173.

281. Trewin, R. R., Jensen, M. K., and Bergles, A. E., 1994, "Experimental Results of Enhanced Bundle Boiling in Binary Mixtures," *Journal of Energy, Heat and Mass Transfer*, Vol. 16, pp. 133-146.

282. Trewin, R. R., Jensen, M. K., and Bergles, A. E., 1994, "Pool Boiling From Enhanced Surfaces in Pure and Binary Mixtures of R-113 and R-11," Presented (poster) at the 10th International Heat Transfer Conference, Brighton, England,

August, *Proceedings of the 10th International Heat Transfer Conference*, Vol. 5, Institution of Chemical Engineers, Rugby, England, pp. 165-170.

283. Carvalho, R. D. M., and Bergles, A. E., 1994, "The Pool Nucleate Boiling Flow Patterns of Vertically Oriented, Small Heaters, Boiling on One Side," Presented (poster) at the 10th International Heat Transfer Conference, Brighton, England, August, *Proceedings of the 10th International Heat Transfer Conference*, Vol. 5, Institution of Chemical Engineers, Rugby, England, pp. 25-30.

284. Ha, S., and Bergles, A. E., 1994, "Some Aspects of Experimental In-Tube Evaporation," Presented (poster) at the 10th International Heat Transfer Conference, Brighton, England, August, *Proceedings of the 10th International Heat Transfer Conference*, Vol. 6, Institution of Chemical Engineers, Rugby, England, pp. 187-192.

285. Lang, S., and Bergles, A. E., 1994, "Transformer Cooler Performance: Analysis and Experiment," Presented at International Joint Power Generation Conference, Phoenix, October 1994, *Heat Exchanger Technologies for the Global Environment*, PWR-Vol. 25, ASME, New York, NY, 1994, pp. 131-140, *Heat Transfer Engineering*, Vol. 16, No. 4, 1995, pp. 28-41.

286. Manglik, R. M., and Bergles, A. E., 1994, "Fully Developed Laminar Heat Transfer in Circular-Segment Ducts," *Numerical Heat Transfer*, Vol. 26, pp. 499-519.

287. Tong, W., Bergles, A. E., and Jensen, M. K., 1994, "Critical Heat Flux and Pressure Drop of Subcooled Flow Boiling in Small Diameter Tubes with Twisted-Tape Inserts," Presented at ASME International Congress, Chicago, November 1994, *Heat Transfer in High Heat Flux Systems*, HTD-Vol. 301, ASME, New York, NY, 1994, pp. 47-58, *Journal of Enhanced Heat Transfer*, Vol. 3, 1996, pp. 95-108.

288. Manglik, R. M., and Bergles, A. E., 1995, "Heat Transfer and Pressure Drop Correlations for the Rectangular Offset Strip Fin Compact Heat Exchanger," *Experimental Thermal and Fluid Science*, Vol. 10, pp. 171-180.

289. MacBain, S. M., and Bergles, A. E., 1995, "Heat Transfer and Pressure Drop Characteristics of Forced Convective Evaporation in Deep Spirally Fluted Tubing," Presented at The Engineering Foundation Conference on Convective Flow Boiling, Banff, Canada, May.

290. Bergles, A. E., and Somerscales, E.F.C., 1995, "The Effect of Fouling on Enhanced Heat Transfer Equipment," *Journal of Enhanced Heat Transfer*, Vol. 2, pp. 157-166.

291. Bergles, A. E., 1995, "Advanced Enhancement for Heat Exchangers," Presented at the Japan-U.S. Seminar on Thermal Engineering for Global Environmental Protection, San Francisco, CA, July.

292. Ravigururan, T. S., and Bergles, A. E., 1995, "Prandtl Number Influence on Heat Transfer Enhancement in Turbulent Flow of Water at Low Temperatures," *Journal of Heat Transfer*, Vol. 117, pp. 276-282.

293. Golobic I., and Bergles, A. E., 1995, "Some Aspects of Heater Side Factors on Pool Boiling Critical Heat Flux," Presented at International Symposium on Two-Phase Flow Modelling and Experimentation, Rome, Italy, October, *Two-Phase Flow Modelling and Experimentation 1995*, Vol. 2, Edizioni ETS, Pisa, Italy, pp. 873-879.

294. Tong, W., Bergles, A. E., and Jensen, M. K., 1995, "Pressure Drop with Highly Subcooled Flow Boiling in Small Diameter Tubes," Presented at International Symposium on Two-Phase Flow Modelling and Experimentation, Rome, Italy, October, *Two-Phase Flow Modelling and Experimentation 1995*, Vol. 1, Edizioni ETS, Pisa, Italy, pp. 617-628.

295. Misale, M., and Bergles, A. E., 1995, "The Influence of Channel Width on Natural Convection and Boiling Heat Transfer from Simulated Microelectronic Components," Presented at International Symposium on Two-Phase Flow Modelling and Experimentation, Rome, Italy, October, *Two-Phase Flow Modelling and Experimentation 1995*, Vol. 2, Edizioni ETS, Pisa, Italy, pp. 1171-1176.

296. Bergles, A. E., 1995, "Heat Transfer Enhancement and Energy Efficiency: Recent Progress and Future Trends," Presented at Sessions on Advances in Enhanced Heat/Mass Transfer, Energy Efficiency, and Process Integration, 1995 ASME Congress and Exposition, San Francisco, CA, November, *Advances in Enhanced Heat/Mass Transfer and Energy Efficiency*, ASME, New York, NY, p. 1.

297. Sarma, P. K., Dharma Rao, V., and Bergles, A. E., 1995, "Turbulent Film Boiling on a Horizontal Cylinder - Effect of Temperature-Dependent Properties," Presented at International Symposium on Advanced Energy Conversion System and Related Technologies (RAN 95), Nagoya, Japan, December.

298. Manglik, R. M., and Bergles, A. E., 1996, "Thermally Developing Laminar Flow Heat Transfer in Circular-Segment Ducts at Constant Wall Temperature," Presented at International Symposium on Transport Phenomena in Thermal-Fluids Engineering, Singapore, June.

299. Lang, S. K., and Bergles, A. E., 1996, "Transformer Cooler Performance with an Air/Water Spray," to be published in *Chemical Engineering Communications*.

300. Bergles, A. E., 1996, "The Encouragement and Accommodation of High Heat Fluxes," Invited Lecture presented at 2nd European Thermal-Sciences and 14th UIT National Heat Transfer Conference, Rome, Italy, May.